

FIRE SAFETY CERTIFICATE CLAUSES 171/174 EP & A REG. 2000

DA No.:	MP08-0236	CC No.:	CC140503-3	
Lot:	4	Section:	Deposited Plan:	1179941
Address:	Googong Water Recycling Plant lot 4 Googong Dam Rd Googong			
Applicant's Name:	Mr S Merange John Holland Pty Ltd			
Applicant's Address:	Googong WRP PO Box 812 Queanbeyan NSW 2620			


SAFETY MEASURES	Date of Assessment	STANDARD OF PERFORMANCE
Emergency lighting	28/01/2016	BCA E4.2 & AS2293.1-2005
Exit signs	28/01/2016	BCA E4.5, E4.6, E4.8 & AS2293.1 2005
Portable fire extinguishers	30/10/2015	BCA E1.6 & AS2444-2001

Assessment Statement:

I Certify that:-

- Each of the essential Fire Safety measures listed above:
- Has been assessed by a person (chosen by me) who was properly qualified to do so and
- Was found, when it was assessed, to have been properly implement and to be capable of performing to a standard not less that required by the most recent fire safety schedule (copy attached for the building for which the certificate is issued.

The information in this certificate is to the best of my knowledge and belief, ture and accurate

Signature  Date: 15/4/16
(Owner/agent)

A copy of this certificate together with the relevant fire safety schedule must be prominently displayed in the building.

CANBERRA

Unit 3, 2-6 Shea Street
Phillip ACT 2606
T (02) 6285 1199
F (02) 6285 2795
E mail@bcacertifiers.com.au

BRISBANE

Unit 12, 58 High Street
PO Box 1703
Toowong QLD 4066
T (07) 3365 0401
F (07) 3365 0498

NEWCASTLE

Level 1, 215-217 Pacific Hwy
PO Box 197
Charlestown NSW 2209
T (02) 4943 1765
F (02) 4943 3845

BCA Certifiers (Aust) Pty Ltd
COLA Lic # 200714
ACN 119 755 734
ABN 58 119 755 734