



FILL CERTIFICATE

PROJECT: Lot No 611 (as per Drawing No 8625 E/06)
Ellery Estate (Stage 6), Wollert

CLIENT: Winslow Constructors Pty Ltd
50 Barry Road
CAMPBELLFIELD VIC 3061

REPORT NO: 22062_611

DATE: 30 May 2023

SUMMARY

Civil Geotechnical Services were engaged by Winslow Constructors Pty Ltd to provide inspection and testing services on the earthworks associated with the construction of Lot 611 of the Ellery Estate (Stage 6), Wollert in a manner which would satisfy the criteria for Level 1 testing and inspection services as specified in Section 8.2 of AS 3798 - Guidelines on earthworks for commercial and residential developments (2007). The project was classified as Type 1/2 requiring a minimum density ratio of 95.0% (standard compactive effort) within the areas of fill placement.

A site inspection was conducted prior to any fill being placed on the Lot. On the completion of the earthworks and after examining the test results and the materials used, we are of the opinion that the filling procedure conducted by Winslow Constructors Pty Ltd satisfied the requirements of the Level 1 criteria specified in AS 3798 in regard to the placement of fill on a Type 1/2 Project.

Accordingly, when classifying the site in accordance with the procedures presented in Section 2 of AS 2870 – Residential slabs and footings (2011), we are of the view that the bulk fill materials that were placed over this Lot by Winslow Constructors Pty Ltd can be considered as having been placed in a controlled manner to a minimum density ratio of 95% (standard compactive effort). As such, the bulk fill materials would be deemed to be controlled fill that complies with Clause 1.8.13 of AS 2870. Hence, re-classification of the site to account for the fill presence is permitted under Clause 2.5.3 (c) of AS 2870.

LIMITATIONS

The use of this Certificate is only appropriate for the field conditions present up to 30 June 2022.

A handwritten signature in blue ink, appearing to read 'Nick Brock', is written over a light blue circular stamp.

Nick Brock



FILL CERTIFICATE

PROJECT: Lot No 612 (as per Drawing No 8625 E/06)
Ellery Estate (Stage 6), Wollert

CLIENT: Winslow Constructors Pty Ltd
50 Barry Road
CAMPBELLFIELD VIC 3061

REPORT NO: 22062_612

DATE: 30 May 2023

SUMMARY

Civil Geotechnical Services were engaged by Winslow Constructors Pty Ltd to provide inspection and testing services on the earthworks associated with the construction of Lot 612 of the Ellery Estate (Stage 6), Wollert in a manner which would satisfy the criteria for Level 1 testing and inspection services as specified in Section 8.2 of AS 3798 - Guidelines on earthworks for commercial and residential developments (2007). The project was classified as Type 1/2 requiring a minimum density ratio of 95.0% (standard compactive effort) within the areas of fill placement.

A site inspection was conducted prior to any fill being placed on the Lot. On the completion of the earthworks and after examining the test results and the materials used, we are of the opinion that the filling procedure conducted by Winslow Constructors Pty Ltd satisfied the requirements of the Level 1 criteria specified in AS 3798 in regard to the placement of fill on a Type 1/2 Project.

Accordingly, when classifying the site in accordance with the procedures presented in Section 2 of AS 2870 – Residential slabs and footings (2011), we are of the view that the bulk fill materials that were placed over this Lot by Winslow Constructors Pty Ltd can be considered as having been placed in a controlled manner to a minimum density ratio of 95% (standard compactive effort). As such, the bulk fill materials would be deemed to be controlled fill that complies with Clause 1.8.13 of AS 2870. Hence, re-classification of the site to account for the fill presence is permitted under Clause 2.5.3 (c) of AS 2870.

LIMITATIONS

The use of this Certificate is only appropriate for the field conditions present up to 30 June 2022.

A handwritten signature in blue ink, appearing to read 'Nick Brock', is written over a light blue circular stamp.

Nick Brock



FILL CERTIFICATE

PROJECT: Lot No 613 (as per Drawing No 8625 E/06)
Ellery Estate (Stage 6), Wollert

CLIENT: Winslow Constructors Pty Ltd
50 Barry Road
CAMPBELLFIELD VIC 3061

REPORT NO: 22062_613

DATE: 30 May 2023

SUMMARY

Civil Geotechnical Services were engaged by Winslow Constructors Pty Ltd to provide inspection and testing services on the earthworks associated with the construction of Lot 613 of the Ellery Estate (Stage 6), Wollert in a manner which would satisfy the criteria for Level 1 testing and inspection services as specified in Section 8.2 of AS 3798 - Guidelines on earthworks for commercial and residential developments (2007). The project was classified as Type 1/2 requiring a minimum density ratio of 95.0% (standard compactive effort) within the areas of fill placement.

A site inspection was conducted prior to any fill being placed on the Lot. On the completion of the earthworks and after examining the test results and the materials used, we are of the opinion that the filling procedure conducted by Winslow Constructors Pty Ltd satisfied the requirements of the Level 1 criteria specified in AS 3798 in regard to the placement of fill on a Type 1/2 Project.

Accordingly, when classifying the site in accordance with the procedures presented in Section 2 of AS 2870 – Residential slabs and footings (2011), we are of the view that the bulk fill materials that were placed over this Lot by Winslow Constructors Pty Ltd can be considered as having been placed in a controlled manner to a minimum density ratio of 95% (standard compactive effort). As such, the bulk fill materials would be deemed to be controlled fill that complies with Clause 1.8.13 of AS 2870. Hence, re-classification of the site to account for the fill presence is permitted under Clause 2.5.3 (c) of AS 2870.

LIMITATIONS

The use of this Certificate is only appropriate for the field conditions present up to 30 June 2022.

A handwritten signature in blue ink, appearing to read 'Nick Brock', is written over a horizontal line.

Nick Brock



FILL CERTIFICATE

PROJECT: Lot No 614 (as per Drawing No 8625 E/06)
Ellery Estate (Stage 6), Wollert

CLIENT: Winslow Constructors Pty Ltd
50 Barry Road
CAMPBELLFIELD VIC 3061

REPORT NO: 22062_614

DATE: 30 May 2023

SUMMARY

Civil Geotechnical Services were engaged by Winslow Constructors Pty Ltd to provide inspection and testing services on the earthworks associated with the construction of Lot 614 of the Ellery Estate (Stage 6), Wollert in a manner which would satisfy the criteria for Level 1 testing and inspection services as specified in Section 8.2 of AS 3798 - Guidelines on earthworks for commercial and residential developments (2007). The project was classified as Type 1/2 requiring a minimum density ratio of 95.0% (standard compactive effort) within the areas of fill placement.

A site inspection was conducted prior to any fill being placed on the Lot. On the completion of the earthworks and after examining the test results and the materials used, we are of the opinion that the filling procedure conducted by Winslow Constructors Pty Ltd satisfied the requirements of the Level 1 criteria specified in AS 3798 in regard to the placement of fill on a Type 1/2 Project.

Accordingly, when classifying the site in accordance with the procedures presented in Section 2 of AS 2870 – Residential slabs and footings (2011), we are of the view that the bulk fill materials that were placed over this Lot by Winslow Constructors Pty Ltd can be considered as having been placed in a controlled manner to a minimum density ratio of 95% (standard compactive effort). As such, the bulk fill materials would be deemed to be controlled fill that complies with Clause 1.8.13 of AS 2870. Hence, re-classification of the site to account for the fill presence is permitted under Clause 2.5.3 (c) of AS 2870.

LIMITATIONS

The use of this Certificate is only appropriate for the field conditions present up to 30 June 2022.

A handwritten signature in blue ink, appearing to read 'Nick Brock', is written over a light blue circular stamp.

Nick Brock



FILL CERTIFICATE

PROJECT: Lot No 615 (as per Drawing No 8625 E/06)
Ellery Estate (Stage 6), Wollert

CLIENT: Winslow Constructors Pty Ltd
50 Barry Road
CAMPBELLFIELD VIC 3061

REPORT NO: 22062_615

DATE: 30 May 2023

SUMMARY

Civil Geotechnical Services were engaged by Winslow Constructors Pty Ltd to provide inspection and testing services on the earthworks associated with the construction of Lot 615 of the Ellery Estate (Stage 6), Wollert in a manner which would satisfy the criteria for Level 1 testing and inspection services as specified in Section 8.2 of AS 3798 - Guidelines on earthworks for commercial and residential developments (2007). The project was classified as Type 1/2 requiring a minimum density ratio of 95.0% (standard compactive effort) within the areas of fill placement.

A site inspection was conducted prior to any fill being placed on the Lot. On the completion of the earthworks and after examining the test results and the materials used, we are of the opinion that the filling procedure conducted by Winslow Constructors Pty Ltd satisfied the requirements of the Level 1 criteria specified in AS 3798 in regard to the placement of fill on a Type 1/2 Project.

Accordingly, when classifying the site in accordance with the procedures presented in Section 2 of AS 2870 – Residential slabs and footings (2011), we are of the view that the bulk fill materials that were placed over this Lot by Winslow Constructors Pty Ltd can be considered as having been placed in a controlled manner to a minimum density ratio of 95% (standard compactive effort). As such, the bulk fill materials would be deemed to be controlled fill that complies with Clause 1.8.13 of AS 2870. Hence, re-classification of the site to account for the fill presence is permitted under Clause 2.5.3 (c) of AS 2870.

LIMITATIONS

The use of this Certificate is only appropriate for the field conditions present up to 30 June 2022.

A handwritten signature in blue ink, appearing to read 'Nick Brock', is written over a light blue circular stamp.

Nick Brock



FILL CERTIFICATE

PROJECT: Lot No 616 (as per Drawing No 8625 E/06)
Ellery Estate (Stage 6), Wollert

CLIENT: Winslow Constructors Pty Ltd
50 Barry Road
CAMPBELLFIELD VIC 3061

REPORT NO: 22062_616

DATE: 30 May 2023

SUMMARY

Civil Geotechnical Services were engaged by Winslow Constructors Pty Ltd to provide inspection and testing services on the earthworks associated with the construction of Lot 616 of the Ellery Estate (Stage 6), Wollert in a manner which would satisfy the criteria for Level 1 testing and inspection services as specified in Section 8.2 of AS 3798 - Guidelines on earthworks for commercial and residential developments (2007). The project was classified as Type 1/2 requiring a minimum density ratio of 95.0% (standard compactive effort) within the areas of fill placement.

A site inspection was conducted prior to any fill being placed on the Lot. On the completion of the earthworks and after examining the test results and the materials used, we are of the opinion that the filling procedure conducted by Winslow Constructors Pty Ltd satisfied the requirements of the Level 1 criteria specified in AS 3798 in regard to the placement of fill on a Type 1/2 Project.

Accordingly, when classifying the site in accordance with the procedures presented in Section 2 of AS 2870 – Residential slabs and footings (2011), we are of the view that the bulk fill materials that were placed over this Lot by Winslow Constructors Pty Ltd can be considered as having been placed in a controlled manner to a minimum density ratio of 95% (standard compactive effort). As such, the bulk fill materials would be deemed to be controlled fill that complies with Clause 1.8.13 of AS 2870. Hence, re-classification of the site to account for the fill presence is permitted under Clause 2.5.3 (c) of AS 2870.

LIMITATIONS

The use of this Certificate is only appropriate for the field conditions present up to 30 June 2022.

A handwritten signature in blue ink, appearing to be 'Nick Brock', is written over a light blue circular stamp.

Nick Brock



FILL CERTIFICATE

PROJECT: Lot No 617 (as per Drawing No 8625 E/06)
Ellery Estate (Stage 6), Wollert

CLIENT: Winslow Constructors Pty Ltd
50 Barry Road
CAMPBELLFIELD VIC 3061

REPORT NO: 22062_617

DATE: 30 May 2023

SUMMARY

Civil Geotechnical Services were engaged by Winslow Constructors Pty Ltd to provide inspection and testing services on the earthworks associated with the construction of Lot 617 of the Ellery Estate (Stage 6), Wollert in a manner which would satisfy the criteria for Level 1 testing and inspection services as specified in Section 8.2 of AS 3798 - Guidelines on earthworks for commercial and residential developments (2007). The project was classified as Type 1/2 requiring a minimum density ratio of 95.0% (standard compactive effort) within the areas of fill placement.

A site inspection was conducted prior to any fill being placed on the Lot. On the completion of the earthworks and after examining the test results and the materials used, we are of the opinion that the filling procedure conducted by Winslow Constructors Pty Ltd satisfied the requirements of the Level 1 criteria specified in AS 3798 in regard to the placement of fill on a Type 1/2 Project.

Accordingly, when classifying the site in accordance with the procedures presented in Section 2 of AS 2870 – Residential slabs and footings (2011), we are of the view that the bulk fill materials that were placed over this Lot by Winslow Constructors Pty Ltd can be considered as having been placed in a controlled manner to a minimum density ratio of 95% (standard compactive effort). As such, the bulk fill materials would be deemed to be controlled fill that complies with Clause 1.8.13 of AS 2870. Hence, re-classification of the site to account for the fill presence is permitted under Clause 2.5.3 (c) of AS 2870.

LIMITATIONS

The use of this Certificate is only appropriate for the field conditions present up to 30 June 2022.

A handwritten signature in blue ink, appearing to read 'Nick Brock', is written over a light blue circular stamp.

Nick Brock



FILL CERTIFICATE

PROJECT: Lot No 618 (as per Drawing No 8625 E/06)
Ellery Estate (Stage 6), Wollert

CLIENT: Winslow Constructors Pty Ltd
50 Barry Road
CAMPBELLFIELD VIC 3061

REPORT NO: 22062_618

DATE: 30 May 2023

SUMMARY

Civil Geotechnical Services were engaged by Winslow Constructors Pty Ltd to provide inspection and testing services on the earthworks associated with the construction of Lot 618 of the Ellery Estate (Stage 6), Wollert in a manner which would satisfy the criteria for Level 1 testing and inspection services as specified in Section 8.2 of AS 3798 - Guidelines on earthworks for commercial and residential developments (2007). The project was classified as Type 1/2 requiring a minimum density ratio of 95.0% (standard compactive effort) within the areas of fill placement.

A site inspection was conducted prior to any fill being placed on the Lot. On the completion of the earthworks and after examining the test results and the materials used, we are of the opinion that the filling procedure conducted by Winslow Constructors Pty Ltd satisfied the requirements of the Level 1 criteria specified in AS 3798 in regard to the placement of fill on a Type 1/2 Project.

Accordingly, when classifying the site in accordance with the procedures presented in Section 2 of AS 2870 – Residential slabs and footings (2011), we are of the view that the bulk fill materials that were placed over this Lot by Winslow Constructors Pty Ltd can be considered as having been placed in a controlled manner to a minimum density ratio of 95% (standard compactive effort). As such, the bulk fill materials would be deemed to be controlled fill that complies with Clause 1.8.13 of AS 2870. Hence, re-classification of the site to account for the fill presence is permitted under Clause 2.5.3 (c) of AS 2870.

LIMITATIONS

The use of this Certificate is only appropriate for the field conditions present up to 30 June 2022.

A handwritten signature in blue ink, appearing to be 'Nick Brock', is written over a light blue circular stamp.

Nick Brock



FILL CERTIFICATE

PROJECT: Lot No 620 (as per Drawing No 8625 E/06)
Ellery Estate (Stage 6), Wollert

CLIENT: Winslow Constructors Pty Ltd
50 Barry Road
CAMPBELLFIELD VIC 3061

REPORT NO: 22062_620

DATE: 30 May 2023

SUMMARY

Civil Geotechnical Services were engaged by Winslow Constructors Pty Ltd to provide inspection and testing services on the earthworks associated with the construction of Lot 620 of the Ellery Estate (Stage 6), Wollert in a manner which would satisfy the criteria for Level 1 testing and inspection services as specified in Section 8.2 of AS 3798 - Guidelines on earthworks for commercial and residential developments (2007). The project was classified as Type 1/2 requiring a minimum density ratio of 95.0% (standard compactive effort) within the areas of fill placement.

A site inspection was conducted prior to any fill being placed on the Lot. On the completion of the earthworks and after examining the test results and the materials used, we are of the opinion that the filling procedure conducted by Winslow Constructors Pty Ltd satisfied the requirements of the Level 1 criteria specified in AS 3798 in regard to the placement of fill on a Type 1/2 Project.

Accordingly, when classifying the site in accordance with the procedures presented in Section 2 of AS 2870 – Residential slabs and footings (2011), we are of the view that the bulk fill materials that were placed over this Lot by Winslow Constructors Pty Ltd can be considered as having been placed in a controlled manner to a minimum density ratio of 95% (standard compactive effort). As such, the bulk fill materials would be deemed to be controlled fill that complies with Clause 1.8.13 of AS 2870. Hence, re-classification of the site to account for the fill presence is permitted under Clause 2.5.3 (c) of AS 2870.

LIMITATIONS

The use of this Certificate is only appropriate for the field conditions present up to 30 June 2022.

A handwritten signature in blue ink, appearing to read 'Nick Brock', is written over a horizontal line.

Nick Brock



FILL CERTIFICATE

PROJECT: Lot No 621 (as per Drawing No 8625 E/06)
Ellery Estate (Stage 6), Wollert

CLIENT: Winslow Constructors Pty Ltd
50 Barry Road
CAMPBELLFIELD VIC 3061

REPORT NO: 22062_621

DATE: 30 May 2023

SUMMARY

Civil Geotechnical Services were engaged by Winslow Constructors Pty Ltd to provide inspection and testing services on the earthworks associated with the construction of Lot 621 of the Ellery Estate (Stage 6), Wollert in a manner which would satisfy the criteria for Level 1 testing and inspection services as specified in Section 8.2 of AS 3798 - Guidelines on earthworks for commercial and residential developments (2007). The project was classified as Type 1/2 requiring a minimum density ratio of 95.0% (standard compactive effort) within the areas of fill placement.

A site inspection was conducted prior to any fill being placed on the Lot. On the completion of the earthworks and after examining the test results and the materials used, we are of the opinion that the filling procedure conducted by Winslow Constructors Pty Ltd satisfied the requirements of the Level 1 criteria specified in AS 3798 in regard to the placement of fill on a Type 1/2 Project.

Accordingly, when classifying the site in accordance with the procedures presented in Section 2 of AS 2870 – Residential slabs and footings (2011), we are of the view that the bulk fill materials that were placed over this Lot by Winslow Constructors Pty Ltd can be considered as having been placed in a controlled manner to a minimum density ratio of 95% (standard compactive effort). As such, the bulk fill materials would be deemed to be controlled fill that complies with Clause 1.8.13 of AS 2870. Hence, re-classification of the site to account for the fill presence is permitted under Clause 2.5.3 (c) of AS 2870.

LIMITATIONS

The use of this Certificate is only appropriate for the field conditions present up to 30 June 2022.

A handwritten signature in blue ink, appearing to be 'Nick Brock', is written over a light blue circular stamp.

Nick Brock



FILL CERTIFICATE

PROJECT: Lot No 622 (as per Drawing No 8625 E/06)
Ellery Estate (Stage 6), Wollert

CLIENT: Winslow Constructors Pty Ltd
50 Barry Road
CAMPBELLFIELD VIC 3061

REPORT NO: 22062_622

DATE: 30 May 2023

SUMMARY

Civil Geotechnical Services were engaged by Winslow Constructors Pty Ltd to provide inspection and testing services on the earthworks associated with the construction of Lot 622 of the Ellery Estate (Stage 6), Wollert in a manner which would satisfy the criteria for Level 1 testing and inspection services as specified in Section 8.2 of AS 3798 - Guidelines on earthworks for commercial and residential developments (2007). The project was classified as Type 1/2 requiring a minimum density ratio of 95.0% (standard compactive effort) within the areas of fill placement.

A site inspection was conducted prior to any fill being placed on the Lot. On the completion of the earthworks and after examining the test results and the materials used, we are of the opinion that the filling procedure conducted by Winslow Constructors Pty Ltd satisfied the requirements of the Level 1 criteria specified in AS 3798 in regard to the placement of fill on a Type 1/2 Project.

Accordingly, when classifying the site in accordance with the procedures presented in Section 2 of AS 2870 – Residential slabs and footings (2011), we are of the view that the bulk fill materials that were placed over this Lot by Winslow Constructors Pty Ltd can be considered as having been placed in a controlled manner to a minimum density ratio of 95% (standard compactive effort). As such, the bulk fill materials would be deemed to be controlled fill that complies with Clause 1.8.13 of AS 2870. Hence, re-classification of the site to account for the fill presence is permitted under Clause 2.5.3 (c) of AS 2870.

LIMITATIONS

The use of this Certificate is only appropriate for the field conditions present up to 30 June 2022.

A handwritten signature in blue ink, appearing to be 'Nick Brock', is written over a horizontal line.

Nick Brock



FILL CERTIFICATE

PROJECT: Lot No 623 (as per Drawing No 8625 E/06)
Ellery Estate (Stage 6), Wollert

CLIENT: Winslow Constructors Pty Ltd
50 Barry Road
CAMPBELLFIELD VIC 3061

REPORT NO: 22062_623

DATE: 30 May 2023

SUMMARY

Civil Geotechnical Services were engaged by Winslow Constructors Pty Ltd to provide inspection and testing services on the earthworks associated with the construction of Lot 623 of the Ellery Estate (Stage 6), Wollert in a manner which would satisfy the criteria for Level 1 testing and inspection services as specified in Section 8.2 of AS 3798 - Guidelines on earthworks for commercial and residential developments (2007). The project was classified as Type 1/2 requiring a minimum density ratio of 95.0% (standard compactive effort) within the areas of fill placement.

A site inspection was conducted prior to any fill being placed on the Lot. On the completion of the earthworks and after examining the test results and the materials used, we are of the opinion that the filling procedure conducted by Winslow Constructors Pty Ltd satisfied the requirements of the Level 1 criteria specified in AS 3798 in regard to the placement of fill on a Type 1/2 Project.

Accordingly, when classifying the site in accordance with the procedures presented in Section 2 of AS 2870 – Residential slabs and footings (2011), we are of the view that the bulk fill materials that were placed over this Lot by Winslow Constructors Pty Ltd can be considered as having been placed in a controlled manner to a minimum density ratio of 95% (standard compactive effort). As such, the bulk fill materials would be deemed to be controlled fill that complies with Clause 1.8.13 of AS 2870. Hence, re-classification of the site to account for the fill presence is permitted under Clause 2.5.3 (c) of AS 2870.

LIMITATIONS

The use of this Certificate is only appropriate for the field conditions present up to 30 June 2022.

A handwritten signature in blue ink, appearing to read 'Nick Brock', is written over a horizontal line.

Nick Brock