



---

## FILL CERTIFICATE

PROJECT: Lot No 202 (as per Drawing No 12369-202-C02)  
Haven Estate (Stage 2), Tarneit

CLIENT: Peets Funds Management Pty Ltd  
Level 3, 492 St Kilda Road  
MELBOURNE VIC 3004

REPORT NO: 16286\_202

DATE: 14/06/16

---

### SUMMARY

Civil Geotechnical Services were engaged by Winslow Constructors Pty Ltd to provide inspection and testing services on the earthworks associated with Lot 202 of Haven Estate (Stage 2), Tarneit, in a manner which would satisfy the criteria for Level 1 Supervision as specified in Section 8.2 of AS 3798 - Guidelines on Earthworks for Commercial and Residential Developments - 2007. The project was classified as Type 1/2 requiring a minimum density ratio of 95.0% (standard compactive effort) within the area of fill placement.

A site inspection was conducted prior to any fill being placed on the Lot. On the completion of earthworks and after examining the test results and the materials used, we are of the opinion that the filling procedure conducted by Winslow Constructors Pty Ltd satisfied the requirements of AS 3798 in regard to the placement of fill on a Type 1/2 Project under Level 1 Supervision.

Accordingly, when classifying the site in accordance with the procedures presented in Section 2 of AS 2870 – Residential Slabs and Footings – Construction (2011), we are of the view that the bulk fill materials that were placed on this Lot by Winslow Constructors Pty Ltd can be considered as being placed in a controlled manner to a minimum density ratio of 95% (standard compactive effort).

### LIMITATIONS

The use of this Certificate is only appropriate for the field conditions present up to 15<sup>th</sup> June 2016.

A handwritten signature in black ink, appearing to read 'Griffin Brown', is written over a light blue horizontal line.

Griffin Brown



---

## FILL CERTIFICATE

PROJECT: Lot No 203 (as per Drawing No 12369-202-C02)  
Haven Estate (Stage 2), Tarneit

CLIENT: Peets Funds Management Pty Ltd  
Level 3, 492 St Kilda Road  
MELBOURNE VIC 3004

REPORT NO: 16286\_203

DATE: 14/06/16

---

### SUMMARY

Civil Geotechnical Services were engaged by Winslow Constructors Pty Ltd to provide inspection and testing services on the earthworks associated with Lot 203 of Haven Estate (Stage 2), Tarneit, in a manner which would satisfy the criteria for Level 1 Supervision as specified in Section 8.2 of AS 3798 - Guidelines on Earthworks for Commercial and Residential Developments - 2007. The project was classified as Type 1/2 requiring a minimum density ratio of 95.0% (standard compactive effort) within the area of fill placement.

A site inspection was conducted prior to any fill being placed on the Lot. On the completion of earthworks and after examining the test results and the materials used, we are of the opinion that the filling procedure conducted by Winslow Constructors Pty Ltd satisfied the requirements of AS 3798 in regard to the placement of fill on a Type 1/2 Project under Level 1 Supervision.

Accordingly, when classifying the site in accordance with the procedures presented in Section 2 of AS 2870 – Residential Slabs and Footings – Construction (2011), we are of the view that the bulk fill materials that were placed on this Lot by Winslow Constructors Pty Ltd can be considered as being placed in a controlled manner to a minimum density ratio of 95% (standard compactive effort).

### LIMITATIONS

The use of this Certificate is only appropriate for the field conditions present up to 15<sup>th</sup> June 2016.

A handwritten signature in black ink, appearing to read 'Griffin Brown'.

Griffin Brown



---

## FILL CERTIFICATE

PROJECT: Lot No 204 (as per Drawing No 12369-202-C02)  
Haven Estate (Stage 2), Tarneit

CLIENT: Peets Funds Management Pty Ltd  
Level 3, 492 St Kilda Road  
MELBOURNE VIC 3004

REPORT NO: 16286\_204

DATE: 14/06/16

---

### SUMMARY

Civil Geotechnical Services were engaged by Winslow Constructors Pty Ltd to provide inspection and testing services on the earthworks associated with Lot 204 of Haven Estate (Stage 2), Tarneit, in a manner which would satisfy the criteria for Level 1 Supervision as specified in Section 8.2 of AS 3798 - Guidelines on Earthworks for Commercial and Residential Developments - 2007. The project was classified as Type 1/2 requiring a minimum density ratio of 95.0% (standard compactive effort) within the area of fill placement.

A site inspection was conducted prior to any fill being placed on the Lot. On the completion of earthworks and after examining the test results and the materials used, we are of the opinion that the filling procedure conducted by Winslow Constructors Pty Ltd satisfied the requirements of AS 3798 in regard to the placement of fill on a Type 1/2 Project under Level 1 Supervision.

Accordingly, when classifying the site in accordance with the procedures presented in Section 2 of AS 2870 – Residential Slabs and Footings – Construction (2011), we are of the view that the bulk fill materials that were placed on this Lot by Winslow Constructors Pty Ltd can be considered as being placed in a controlled manner to a minimum density ratio of 95% (standard compactive effort).

### LIMITATIONS

The use of this Certificate is only appropriate for the field conditions present up to 15<sup>th</sup> June 2016.

A handwritten signature in black ink, appearing to read 'Griffin Brown', is written over a light blue horizontal line.

Griffin Brown



---

## FILL CERTIFICATE

PROJECT: Lot No 206 (as per Drawing No 12369-202-C02)  
Haven Estate (Stage 2), Tarneit

CLIENT: Peets Funds Management Pty Ltd  
Level 3, 492 St Kilda Road  
MELBOURNE VIC 3004

REPORT NO: 16286\_206

DATE: 14/06/16

---

### SUMMARY

Civil Geotechnical Services were engaged by Winslow Constructors Pty Ltd to provide inspection and testing services on the earthworks associated with Lot 206 of Haven Estate (Stage 2), Tarneit, in a manner which would satisfy the criteria for Level 1 Supervision as specified in Section 8.2 of AS 3798 - Guidelines on Earthworks for Commercial and Residential Developments - 2007. The project was classified as Type 1/2 requiring a minimum density ratio of 95.0% (standard compactive effort) within the area of fill placement.

A site inspection was conducted prior to any fill being placed on the Lot. On the completion of earthworks and after examining the test results and the materials used, we are of the opinion that the filling procedure conducted by Winslow Constructors Pty Ltd satisfied the requirements of AS 3798 in regard to the placement of fill on a Type 1/2 Project under Level 1 Supervision.

Accordingly, when classifying the site in accordance with the procedures presented in Section 2 of AS 2870 – Residential Slabs and Footings – Construction (2011), we are of the view that the bulk fill materials that were placed on this Lot by Winslow Constructors Pty Ltd can be considered as being placed in a controlled manner to a minimum density ratio of 95% (standard compactive effort).

### LIMITATIONS

The use of this Certificate is only appropriate for the field conditions present up to 15<sup>th</sup> June 2016.

A handwritten signature in black ink, appearing to read 'Griffin Brown', is written over a light blue horizontal line.

Griffin Brown



---

## FILL CERTIFICATE

PROJECT: Lot No 207 (as per Drawing No 12369-202-C02)  
Haven Estate (Stage 2), Tarneit

CLIENT: Peets Funds Management Pty Ltd  
Level 3, 492 St Kilda Road  
MELBOURNE VIC 3004

REPORT NO: 16286\_207

DATE: 14/06/16

---

### SUMMARY

Civil Geotechnical Services were engaged by Winslow Constructors Pty Ltd to provide inspection and testing services on the earthworks associated with Lot 207 of Haven Estate (Stage 2), Tarneit, in a manner which would satisfy the criteria for Level 1 Supervision as specified in Section 8.2 of AS 3798 - Guidelines on Earthworks for Commercial and Residential Developments - 2007. The project was classified as Type 1/2 requiring a minimum density ratio of 95.0% (standard compactive effort) within the area of fill placement.

A site inspection was conducted prior to any fill being placed on the Lot. On the completion of earthworks and after examining the test results and the materials used, we are of the opinion that the filling procedure conducted by Winslow Constructors Pty Ltd satisfied the requirements of AS 3798 in regard to the placement of fill on a Type 1/2 Project under Level 1 Supervision.

Accordingly, when classifying the site in accordance with the procedures presented in Section 2 of AS 2870 – Residential Slabs and Footings – Construction (2011), we are of the view that the bulk fill materials that were placed on this Lot by Winslow Constructors Pty Ltd can be considered as being placed in a controlled manner to a minimum density ratio of 95% (standard compactive effort).

### LIMITATIONS

The use of this Certificate is only appropriate for the field conditions present up to 15<sup>th</sup> June 2016.

A handwritten signature in black ink, appearing to read 'Griffin Brown', is written over a light blue horizontal line.

Griffin Brown



---

## FILL CERTIFICATE

PROJECT: Lot No 208 (as per Drawing No 12369-202-C02)  
Haven Estate (Stage 2), Tarneit

CLIENT: Peets Funds Management Pty Ltd  
Level 3, 492 St Kilda Road  
MELBOURNE VIC 3004

REPORT NO: 16286\_208

DATE: 14/06/16

---

### SUMMARY

Civil Geotechnical Services were engaged by Winslow Constructors Pty Ltd to provide inspection and testing services on the earthworks associated with Lot 208 of Haven Estate (Stage 2), Tarneit, in a manner which would satisfy the criteria for Level 1 Supervision as specified in Section 8.2 of AS 3798 - Guidelines on Earthworks for Commercial and Residential Developments - 2007. The project was classified as Type 1/2 requiring a minimum density ratio of 95.0% (standard compactive effort) within the area of fill placement.

A site inspection was conducted prior to any fill being placed on the Lot. On the completion of earthworks and after examining the test results and the materials used, we are of the opinion that the filling procedure conducted by Winslow Constructors Pty Ltd satisfied the requirements of AS 3798 in regard to the placement of fill on a Type 1/2 Project under Level 1 Supervision.

Accordingly, when classifying the site in accordance with the procedures presented in Section 2 of AS 2870 – Residential Slabs and Footings – Construction (2011), we are of the view that the bulk fill materials that were placed on this Lot by Winslow Constructors Pty Ltd can be considered as being placed in a controlled manner to a minimum density ratio of 95% (standard compactive effort).

### LIMITATIONS

The use of this Certificate is only appropriate for the field conditions present up to 15<sup>th</sup> June 2016.

A handwritten signature in black ink, appearing to read 'Griffin Brown', is written over a light blue horizontal line.

Griffin Brown



---

## FILL CERTIFICATE

PROJECT: Lot No 209 (as per Drawing No 12369-202-C02)  
Haven Estate (Stage 2), Tarneit

CLIENT: Peets Funds Management Pty Ltd  
Level 3, 492 St Kilda Road  
MELBOURNE VIC 3004

REPORT NO: 16286\_209

DATE: 14/06/16

---

### SUMMARY

Civil Geotechnical Services were engaged by Winslow Constructors Pty Ltd to provide inspection and testing services on the earthworks associated with Lot 209 of Haven Estate (Stage 2), Tarneit, in a manner which would satisfy the criteria for Level 1 Supervision as specified in Section 8.2 of AS 3798 - Guidelines on Earthworks for Commercial and Residential Developments - 2007. The project was classified as Type 1/2 requiring a minimum density ratio of 95.0% (standard compactive effort) within the area of fill placement.

A site inspection was conducted prior to any fill being placed on the Lot. On the completion of earthworks and after examining the test results and the materials used, we are of the opinion that the filling procedure conducted by Winslow Constructors Pty Ltd satisfied the requirements of AS 3798 in regard to the placement of fill on a Type 1/2 Project under Level 1 Supervision.

Accordingly, when classifying the site in accordance with the procedures presented in Section 2 of AS 2870 – Residential Slabs and Footings – Construction (2011), we are of the view that the bulk fill materials that were placed on this Lot by Winslow Constructors Pty Ltd can be considered as being placed in a controlled manner to a minimum density ratio of 95% (standard compactive effort).

### LIMITATIONS

The use of this Certificate is only appropriate for the field conditions present up to 15<sup>th</sup> June 2016.

A handwritten signature in black ink, appearing to read 'Griffin Brown', is written over a light blue horizontal line.

Griffin Brown



---

## FILL CERTIFICATE

PROJECT: Lot No 210 (as per Drawing No 12369-202-C02)  
Haven Estate (Stage 2), Tarneit

CLIENT: Peets Funds Management Pty Ltd  
Level 3, 492 St Kilda Road  
MELBOURNE VIC 3004

REPORT NO: 16286\_210

DATE: 14/06/16

---

### SUMMARY

Civil Geotechnical Services were engaged by Winslow Constructors Pty Ltd to provide inspection and testing services on the earthworks associated with Lot 210 of Haven Estate (Stage 2), Tarneit, in a manner which would satisfy the criteria for Level 1 Supervision as specified in Section 8.2 of AS 3798 - Guidelines on Earthworks for Commercial and Residential Developments - 2007. The project was classified as Type 1/2 requiring a minimum density ratio of 95.0% (standard compactive effort) within the area of fill placement.

A site inspection was conducted prior to any fill being placed on the Lot. On the completion of earthworks and after examining the test results and the materials used, we are of the opinion that the filling procedure conducted by Winslow Constructors Pty Ltd satisfied the requirements of AS 3798 in regard to the placement of fill on a Type 1/2 Project under Level 1 Supervision.

Accordingly, when classifying the site in accordance with the procedures presented in Section 2 of AS 2870 – Residential Slabs and Footings – Construction (2011), we are of the view that the bulk fill materials that were placed on this Lot by Winslow Constructors Pty Ltd can be considered as being placed in a controlled manner to a minimum density ratio of 95% (standard compactive effort).

### LIMITATIONS

The use of this Certificate is only appropriate for the field conditions present up to 15<sup>th</sup> June 2016.

A handwritten signature in black ink, appearing to read 'Griffin Brown', is written over a light blue horizontal line.

Griffin Brown



---

## FILL CERTIFICATE

PROJECT: Lot No 211 (as per Drawing No 12369-202-C02)  
Haven Estate (Stage 2), Tarneit

CLIENT: Peets Funds Management Pty Ltd  
Level 3, 492 St Kilda Road  
MELBOURNE VIC 3004

REPORT NO: 16286\_211

DATE: 14/06/16

---

### SUMMARY

Civil Geotechnical Services were engaged by Winslow Constructors Pty Ltd to provide inspection and testing services on the earthworks associated with Lot 211 of Haven Estate (Stage 2), Tarneit, in a manner which would satisfy the criteria for Level 1 Supervision as specified in Section 8.2 of AS 3798 - Guidelines on Earthworks for Commercial and Residential Developments - 2007. The project was classified as Type 1/2 requiring a minimum density ratio of 95.0% (standard compactive effort) within the area of fill placement.

A site inspection was conducted prior to any fill being placed on the Lot. On the completion of earthworks and after examining the test results and the materials used, we are of the opinion that the filling procedure conducted by Winslow Constructors Pty Ltd satisfied the requirements of AS 3798 in regard to the placement of fill on a Type 1/2 Project under Level 1 Supervision.

Accordingly, when classifying the site in accordance with the procedures presented in Section 2 of AS 2870 – Residential Slabs and Footings – Construction (2011), we are of the view that the bulk fill materials that were placed on this Lot by Winslow Constructors Pty Ltd can be considered as being placed in a controlled manner to a minimum density ratio of 95% (standard compactive effort).

### LIMITATIONS

The use of this Certificate is only appropriate for the field conditions present up to June 2016.

A handwritten signature in black ink, appearing to read 'Griffin Brown', is written over a light blue horizontal line.

Griffin Brown



---

## FILL CERTIFICATE

PROJECT: Lot No 212 (as per Drawing No 12369-202-C02)  
Haven Estate (Stage 2), Tarneit

CLIENT: Peets Funds Management Pty Ltd  
Level 3, 492 St Kilda Road  
MELBOURNE VIC 3004

REPORT NO: 16286\_212

DATE: 14/06/16

---

### SUMMARY

Civil Geotechnical Services were engaged by Winslow Constructors Pty Ltd to provide inspection and testing services on the earthworks associated with Lot 212 of Haven Estate (Stage 2), Tarneit, in a manner which would satisfy the criteria for Level 1 Supervision as specified in Section 8.2 of AS 3798 - Guidelines on Earthworks for Commercial and Residential Developments - 2007. The project was classified as Type 1/2 requiring a minimum density ratio of 95.0% (standard compactive effort) within the area of fill placement.

A site inspection was conducted prior to any fill being placed on the Lot. On the completion of earthworks and after examining the test results and the materials used, we are of the opinion that the filling procedure conducted by Winslow Constructors Pty Ltd satisfied the requirements of AS 3798 in regard to the placement of fill on a Type 1/2 Project under Level 1 Supervision.

Accordingly, when classifying the site in accordance with the procedures presented in Section 2 of AS 2870 – Residential Slabs and Footings – Construction (2011), we are of the view that the bulk fill materials that were placed on this Lot by Winslow Constructors Pty Ltd can be considered as being placed in a controlled manner to a minimum density ratio of 95% (standard compactive effort).

### LIMITATIONS

The use of this Certificate is only appropriate for the field conditions present up to June 2016.

A handwritten signature in black ink, appearing to read 'Griffin Brown', is written over a light blue horizontal line.

Griffin Brown



---

## FILL CERTIFICATE

PROJECT: Lot No 214 (as per Drawing No 12369-202-C02)  
Haven Estate (Stage 2), Tarneit

CLIENT: Peets Funds Management Pty Ltd  
Level 3, 492 St Kilda Road  
MELBOURNE VIC 3004

REPORT NO: 16286\_214

DATE: 14/06/16

---

### SUMMARY

Civil Geotechnical Services were engaged by Winslow Constructors Pty Ltd to provide inspection and testing services on the earthworks associated with Lot 214 of Haven Estate (Stage 2), Tarneit, in a manner which would satisfy the criteria for Level 1 Supervision as specified in Section 8.2 of AS 3798 - Guidelines on Earthworks for Commercial and Residential Developments - 2007. The project was classified as Type 1/2 requiring a minimum density ratio of 95.0% (standard compactive effort) within the area of fill placement.

A site inspection was conducted prior to any fill being placed on the Lot. On the completion of earthworks and after examining the test results and the materials used, we are of the opinion that the filling procedure conducted by Winslow Constructors Pty Ltd satisfied the requirements of AS 3798 in regard to the placement of fill on a Type 1/2 Project under Level 1 Supervision.

Accordingly, when classifying the site in accordance with the procedures presented in Section 2 of AS 2870 – Residential Slabs and Footings – Construction (2011), we are of the view that the bulk fill materials that were placed on this Lot by Winslow Constructors Pty Ltd can be considered as being placed in a controlled manner to a minimum density ratio of 95% (standard compactive effort).

### LIMITATIONS

The use of this Certificate is only appropriate for the field conditions present up to June 2016.

A handwritten signature in black ink, appearing to read 'Griffin Brown', written in a cursive style.

Griffin Brown



---

## FILL CERTIFICATE

PROJECT: Lot No 215 (as per Drawing No 12369-202-C02)  
Haven Estate (Stage 2), Tarneit

CLIENT: Peets Funds Management Pty Ltd  
Level 3, 492 St Kilda Road  
MELBOURNE VIC 3004

REPORT NO: 16286\_215

DATE: 14/06/16

---

### SUMMARY

Civil Geotechnical Services were engaged by Winslow Constructors Pty Ltd to provide inspection and testing services on the earthworks associated with Lot 215 of Haven Estate (Stage 2), Tarneit, in a manner which would satisfy the criteria for Level 1 Supervision as specified in Section 8.2 of AS 3798 - Guidelines on Earthworks for Commercial and Residential Developments - 2007. The project was classified as Type 1/2 requiring a minimum density ratio of 95.0% (standard compactive effort) within the area of fill placement.

A site inspection was conducted prior to any fill being placed on the Lot. On the completion of earthworks and after examining the test results and the materials used, we are of the opinion that the filling procedure conducted by Winslow Constructors Pty Ltd satisfied the requirements of AS 3798 in regard to the placement of fill on a Type 1/2 Project under Level 1 Supervision.

Accordingly, when classifying the site in accordance with the procedures presented in Section 2 of AS 2870 – Residential Slabs and Footings – Construction (2011), we are of the view that the bulk fill materials that were placed on this Lot by Winslow Constructors Pty Ltd can be considered as being placed in a controlled manner to a minimum density ratio of 95% (standard compactive effort).

### LIMITATIONS

The use of this Certificate is only appropriate for the field conditions present up to June 2016.

A handwritten signature in black ink, appearing to read 'Griffin Brown'.

Griffin Brown



---

## FILL CERTIFICATE

PROJECT: Lot No 217 (as per Drawing No 12369-202-C02)  
Haven Estate (Stage 2), Tarneit

CLIENT: Peets Funds Management Pty Ltd  
Level 3, 492 St Kilda Road  
MELBOURNE VIC 3004

REPORT NO: 16286\_217

DATE: 14/06/16

---

### SUMMARY

Civil Geotechnical Services were engaged by Winslow Constructors Pty Ltd to provide inspection and testing services on the earthworks associated with Lot 217 of Haven Estate (Stage 2), Tarneit, in a manner which would satisfy the criteria for Level 1 Supervision as specified in Section 8.2 of AS 3798 - Guidelines on Earthworks for Commercial and Residential Developments - 2007. The project was classified as Type 1/2 requiring a minimum density ratio of 95.0% (standard compactive effort) within the area of fill placement.

A site inspection was conducted prior to any fill being placed on the Lot. On the completion of earthworks and after examining the test results and the materials used, we are of the opinion that the filling procedure conducted by Winslow Constructors Pty Ltd satisfied the requirements of AS 3798 in regard to the placement of fill on a Type 1/2 Project under Level 1 Supervision.

Accordingly, when classifying the site in accordance with the procedures presented in Section 2 of AS 2870 – Residential Slabs and Footings – Construction (2011), we are of the view that the bulk fill materials that were placed on this Lot by Winslow Constructors Pty Ltd can be considered as being placed in a controlled manner to a minimum density ratio of 95% (standard compactive effort).

### LIMITATIONS

The use of this Certificate is only appropriate for the field conditions present up to June 2016.

A handwritten signature in black ink, appearing to read 'Griffin Brown', is written over a light blue horizontal line.

Griffin Brown



---

## FILL CERTIFICATE

PROJECT: Lot No 218 (as per Drawing No 12369-202-C02)  
Haven Estate (Stage 2), Tarneit

CLIENT: Peets Funds Management Pty Ltd  
Level 3, 492 St Kilda Road  
MELBOURNE VIC 3004

REPORT NO: 16286\_218

DATE: 14/06/16

---

### SUMMARY

Civil Geotechnical Services were engaged by Winslow Constructors Pty Ltd to provide inspection and testing services on the earthworks associated with Lot 218 of Haven Estate (Stage 2), Tarneit, in a manner which would satisfy the criteria for Level 1 Supervision as specified in Section 8.2 of AS 3798 - Guidelines on Earthworks for Commercial and Residential Developments - 2007. The project was classified as Type 1/2 requiring a minimum density ratio of 95.0% (standard compactive effort) within the area of fill placement.

A site inspection was conducted prior to any fill being placed on the Lot. On the completion of earthworks and after examining the test results and the materials used, we are of the opinion that the filling procedure conducted by Winslow Constructors Pty Ltd satisfied the requirements of AS 3798 in regard to the placement of fill on a Type 1/2 Project under Level 1 Supervision.

Accordingly, when classifying the site in accordance with the procedures presented in Section 2 of AS 2870 – Residential Slabs and Footings – Construction (2011), we are of the view that the bulk fill materials that were placed on this Lot by Winslow Constructors Pty Ltd can be considered as being placed in a controlled manner to a minimum density ratio of 95% (standard compactive effort).

### LIMITATIONS

The use of this Certificate is only appropriate for the field conditions present up to June 2016.

A handwritten signature in black ink, appearing to read 'Griffin Brown', written in a cursive style.

Griffin Brown



## FILL CERTIFICATE

PROJECT: Lot No 219 (as per Drawing No 12369-202-C02)  
Haven Estate (Stage 2), Tarneit

CLIENT: Peets Funds Management Pty Ltd  
Level 3, 492 St Kilda Road  
MELBOURNE VIC 3004

REPORT NO: 16286\_219

DATE: 14/06/16

---

### SUMMARY

Civil Geotechnical Services were engaged by Winslow Constructors Pty Ltd to provide inspection and testing services on the earthworks associated with Lot 219 of Haven Estate (Stage 2), Tarneit, in a manner which would satisfy the criteria for Level 1 Supervision as specified in Section 8.2 of AS 3798 - Guidelines on Earthworks for Commercial and Residential Developments - 2007. The project was classified as Type 1/2 requiring a minimum density ratio of 95.0% (standard compactive effort) within the area of fill placement.

A site inspection was conducted prior to any fill being placed on the Lot. On the completion of earthworks and after examining the test results and the materials used, we are of the opinion that the filling procedure conducted by Winslow Constructors Pty Ltd satisfied the requirements of AS 3798 in regard to the placement of fill on a Type 1/2 Project under Level 1 Supervision.

Accordingly, when classifying the site in accordance with the procedures presented in Section 2 of AS 2870 – Residential Slabs and Footings – Construction (2011), we are of the view that the bulk fill materials that were placed on this Lot by Winslow Constructors Pty Ltd can be considered as being placed in a controlled manner to a minimum density ratio of 95% (standard compactive effort).

### LIMITATIONS

The use of this Certificate is only appropriate for the field conditions present up to June 2016.

A handwritten signature in black ink, appearing to read 'Griffin Brown'.

Griffin Brown



---

## FILL CERTIFICATE

PROJECT: Lot No 220 (as per Drawing No 12369-202-C02)  
Haven Estate (Stage 2), Tarneit

CLIENT: Peets Funds Management Pty Ltd  
Level 3, 492 St Kilda Road  
MELBOURNE VIC 3004

REPORT NO: 16286\_220

DATE: 14/06/16

---

### SUMMARY

Civil Geotechnical Services were engaged by Winslow Constructors Pty Ltd to provide inspection and testing services on the earthworks associated with Lot 220 of Haven Estate (Stage 2), Tarneit, in a manner which would satisfy the criteria for Level 1 Supervision as specified in Section 8.2 of AS 3798 - Guidelines on Earthworks for Commercial and Residential Developments - 2007. The project was classified as Type 1/2 requiring a minimum density ratio of 95.0% (standard compactive effort) within the area of fill placement.

A site inspection was conducted prior to any fill being placed on the Lot. On the completion of earthworks and after examining the test results and the materials used, we are of the opinion that the filling procedure conducted by Winslow Constructors Pty Ltd satisfied the requirements of AS 3798 in regard to the placement of fill on a Type 1/2 Project under Level 1 Supervision.

Accordingly, when classifying the site in accordance with the procedures presented in Section 2 of AS 2870 – Residential Slabs and Footings – Construction (2011), we are of the view that the bulk fill materials that were placed on this Lot by Winslow Constructors Pty Ltd can be considered as being placed in a controlled manner to a minimum density ratio of 95% (standard compactive effort).

### LIMITATIONS

The use of this Certificate is only appropriate for the field conditions present up to June 2016.

A handwritten signature in black ink, appearing to read 'Griffin Brown', written in a cursive style.

Griffin Brown



---

## FILL CERTIFICATE

PROJECT: Lot No 221 (as per Drawing No 12369-202-C02)  
Haven Estate (Stage 2), Tarneit

CLIENT: Peets Funds Management Pty Ltd  
Level 3, 492 St Kilda Road  
MELBOURNE VIC 3004

REPORT NO: 16286\_221

DATE: 14/06/16

---

### SUMMARY

Civil Geotechnical Services were engaged by Winslow Constructors Pty Ltd to provide inspection and testing services on the earthworks associated with Lot 221 of Haven Estate (Stage 2), Tarneit, in a manner which would satisfy the criteria for Level 1 Supervision as specified in Section 8.2 of AS 3798 - Guidelines on Earthworks for Commercial and Residential Developments - 2007. The project was classified as Type 1/2 requiring a minimum density ratio of 95.0% (standard compactive effort) within the area of fill placement.

A site inspection was conducted prior to any fill being placed on the Lot. On the completion of earthworks and after examining the test results and the materials used, we are of the opinion that the filling procedure conducted by Winslow Constructors Pty Ltd satisfied the requirements of AS 3798 in regard to the placement of fill on a Type 1/2 Project under Level 1 Supervision.

Accordingly, when classifying the site in accordance with the procedures presented in Section 2 of AS 2870 – Residential Slabs and Footings – Construction (2011), we are of the view that the bulk fill materials that were placed on this Lot by Winslow Constructors Pty Ltd can be considered as being placed in a controlled manner to a minimum density ratio of 95% (standard compactive effort).

### LIMITATIONS

The use of this Certificate is only appropriate for the field conditions present up to June 2016.

A handwritten signature in black ink, appearing to read 'Griffin Brown', is written over a light blue horizontal line.

Griffin Brown



---

## FILL CERTIFICATE

PROJECT: Lot No 222 (as per Drawing No 12369-202-C02)  
Haven Estate (Stage 2), Tarneit

CLIENT: Peets Funds Management Pty Ltd  
Level 3, 492 St Kilda Road  
MELBOURNE VIC 3004

REPORT NO: 16286\_222

DATE: 14/06/16

---

### SUMMARY

Civil Geotechnical Services were engaged by Winslow Constructors Pty Ltd to provide inspection and testing services on the earthworks associated with Lot 222 of Haven Estate (Stage 2), Tarneit, in a manner which would satisfy the criteria for Level 1 Supervision as specified in Section 8.2 of AS 3798 - Guidelines on Earthworks for Commercial and Residential Developments - 2007. The project was classified as Type 1/2 requiring a minimum density ratio of 95.0% (standard compactive effort) within the area of fill placement.

A site inspection was conducted prior to any fill being placed on the Lot. On the completion of earthworks and after examining the test results and the materials used, we are of the opinion that the filling procedure conducted by Winslow Constructors Pty Ltd satisfied the requirements of AS 3798 in regard to the placement of fill on a Type 1/2 Project under Level 1 Supervision.

Accordingly, when classifying the site in accordance with the procedures presented in Section 2 of AS 2870 – Residential Slabs and Footings – Construction (2011), we are of the view that the bulk fill materials that were placed on this Lot by Winslow Constructors Pty Ltd can be considered as being placed in a controlled manner to a minimum density ratio of 95% (standard compactive effort).

### LIMITATIONS

The use of this Certificate is only appropriate for the field conditions present up to June 2016.

A handwritten signature in black ink, appearing to read 'Griffin Brown', is written over a light blue horizontal line.

Griffin Brown



---

## FILL CERTIFICATE

PROJECT: Lot No 223 (as per Drawing No 12369-202-C02)  
Haven Estate (Stage 2), Tarneit

CLIENT: Peets Funds Management Pty Ltd  
Level 3, 492 St Kilda Road  
MELBOURNE VIC 3004

REPORT NO: 16286\_223

DATE: 14/06/16

---

### SUMMARY

Civil Geotechnical Services were engaged by Winslow Constructors Pty Ltd to provide inspection and testing services on the earthworks associated with Lot 223 of Haven Estate (Stage 2), Tarneit, in a manner which would satisfy the criteria for Level 1 Supervision as specified in Section 8.2 of AS 3798 - Guidelines on Earthworks for Commercial and Residential Developments - 2007. The project was classified as Type 1/2 requiring a minimum density ratio of 95.0% (standard compactive effort) within the area of fill placement.

A site inspection was conducted prior to any fill being placed on the Lot. On the completion of earthworks and after examining the test results and the materials used, we are of the opinion that the filling procedure conducted by Winslow Constructors Pty Ltd satisfied the requirements of AS 3798 in regard to the placement of fill on a Type 1/2 Project under Level 1 Supervision.

Accordingly, when classifying the site in accordance with the procedures presented in Section 2 of AS 2870 – Residential Slabs and Footings – Construction (2011), we are of the view that the bulk fill materials that were placed on this Lot by Winslow Constructors Pty Ltd can be considered as being placed in a controlled manner to a minimum density ratio of 95% (standard compactive effort).

### LIMITATIONS

The use of this Certificate is only appropriate for the field conditions present up to June 2016.

A handwritten signature in black ink, appearing to read 'Griffin Brown', is written over a light blue horizontal line.

Griffin Brown



---

## FILL CERTIFICATE

PROJECT: Lot No 224 (as per Drawing No 12369-202-C02)  
Haven Estate (Stage 2), Tarneit

CLIENT: Peets Funds Management Pty Ltd  
Level 3, 492 St Kilda Road  
MELBOURNE VIC 3004

REPORT NO: 16286\_224

DATE: 14/06/16

---

### SUMMARY

Civil Geotechnical Services were engaged by Winslow Constructors Pty Ltd to provide inspection and testing services on the earthworks associated with Lot 224 of Haven Estate (Stage 2), Tarneit, in a manner which would satisfy the criteria for Level 1 Supervision as specified in Section 8.2 of AS 3798 - Guidelines on Earthworks for Commercial and Residential Developments - 2007. The project was classified as Type 1/2 requiring a minimum density ratio of 95.0% (standard compactive effort) within the area of fill placement.

A site inspection was conducted prior to any fill being placed on the Lot. On the completion of earthworks and after examining the test results and the materials used, we are of the opinion that the filling procedure conducted by Winslow Constructors Pty Ltd satisfied the requirements of AS 3798 in regard to the placement of fill on a Type 1/2 Project under Level 1 Supervision.

Accordingly, when classifying the site in accordance with the procedures presented in Section 2 of AS 2870 – Residential Slabs and Footings – Construction (2011), we are of the view that the bulk fill materials that were placed on this Lot by Winslow Constructors Pty Ltd can be considered as being placed in a controlled manner to a minimum density ratio of 95% (standard compactive effort).

### LIMITATIONS

The use of this Certificate is only appropriate for the field conditions present up to June 2016.

A handwritten signature in black ink, appearing to read 'Griffin Brown', is written over a light blue horizontal line.

Griffin Brown



---

## FILL CERTIFICATE

PROJECT: Lot No 225 (as per Drawing No 12369-202-C02)  
Haven Estate (Stage 2), Tarneit

CLIENT: Peets Funds Management Pty Ltd  
Level 3, 492 St Kilda Road  
MELBOURNE VIC 3004

REPORT NO: 16286\_225

DATE: 14/06/16

---

### SUMMARY

Civil Geotechnical Services were engaged by Winslow Constructors Pty Ltd to provide inspection and testing services on the earthworks associated with Lot 225 of Haven Estate (Stage 2), Tarneit, in a manner which would satisfy the criteria for Level 1 Supervision as specified in Section 8.2 of AS 3798 - Guidelines on Earthworks for Commercial and Residential Developments - 2007. The project was classified as Type 1/2 requiring a minimum density ratio of 95.0% (standard compactive effort) within the area of fill placement.

A site inspection was conducted prior to any fill being placed on the Lot. On the completion of earthworks and after examining the test results and the materials used, we are of the opinion that the filling procedure conducted by Winslow Constructors Pty Ltd satisfied the requirements of AS 3798 in regard to the placement of fill on a Type 1/2 Project under Level 1 Supervision.

Accordingly, when classifying the site in accordance with the procedures presented in Section 2 of AS 2870 – Residential Slabs and Footings – Construction (2011), we are of the view that the bulk fill materials that were placed on this Lot by Winslow Constructors Pty Ltd can be considered as being placed in a controlled manner to a minimum density ratio of 95% (standard compactive effort).

### LIMITATIONS

The use of this Certificate is only appropriate for the field conditions present up to June 2016.

A handwritten signature in black ink, appearing to read 'Griffin Brown', written in a cursive style.

Griffin Brown



---

## FILL CERTIFICATE

PROJECT: Lot No 226 (as per Drawing No 12369-202-C02)  
Haven Estate (Stage 2), Tarneit

CLIENT: Peets Funds Management Pty Ltd  
Level 3, 492 St Kilda Road  
MELBOURNE VIC 3004

REPORT NO: 16286\_226

DATE: 14/06/16

---

### SUMMARY

Civil Geotechnical Services were engaged by Winslow Constructors Pty Ltd to provide inspection and testing services on the earthworks associated with Lot 226 of Haven Estate (Stage 2), Tarneit, in a manner which would satisfy the criteria for Level 1 Supervision as specified in Section 8.2 of AS 3798 - Guidelines on Earthworks for Commercial and Residential Developments - 2007. The project was classified as Type 1/2 requiring a minimum density ratio of 95.0% (standard compactive effort) within the area of fill placement.

A site inspection was conducted prior to any fill being placed on the Lot. On the completion of earthworks and after examining the test results and the materials used, we are of the opinion that the filling procedure conducted by Winslow Constructors Pty Ltd satisfied the requirements of AS 3798 in regard to the placement of fill on a Type 1/2 Project under Level 1 Supervision.

Accordingly, when classifying the site in accordance with the procedures presented in Section 2 of AS 2870 – Residential Slabs and Footings – Construction (2011), we are of the view that the bulk fill materials that were placed on this Lot by Winslow Constructors Pty Ltd can be considered as being placed in a controlled manner to a minimum density ratio of 95% (standard compactive effort).

### LIMITATIONS

The use of this Certificate is only appropriate for the field conditions present up to June 2016.

A handwritten signature in black ink, appearing to read 'Griffin Brown', written in a cursive style.

Griffin Brown



---

## FILL CERTIFICATE

PROJECT: Lot No 227 (as per Drawing No 12369-202-C02)  
Haven Estate (Stage 2), Tarneit

CLIENT: Peets Funds Management Pty Ltd  
Level 3, 492 St Kilda Road  
MELBOURNE VIC 3004

REPORT NO: 16286\_227

DATE: 14/06/16

---

### SUMMARY

Civil Geotechnical Services were engaged by Winslow Constructors Pty Ltd to provide inspection and testing services on the earthworks associated with Lot 227 of Haven Estate (Stage 2), Tarneit, in a manner which would satisfy the criteria for Level 1 Supervision as specified in Section 8.2 of AS 3798 - Guidelines on Earthworks for Commercial and Residential Developments - 2007. The project was classified as Type 1/2 requiring a minimum density ratio of 95.0% (standard compactive effort) within the area of fill placement.

A site inspection was conducted prior to any fill being placed on the Lot. On the completion of earthworks and after examining the test results and the materials used, we are of the opinion that the filling procedure conducted by Winslow Constructors Pty Ltd satisfied the requirements of AS 3798 in regard to the placement of fill on a Type 1/2 Project under Level 1 Supervision.

Accordingly, when classifying the site in accordance with the procedures presented in Section 2 of AS 2870 – Residential Slabs and Footings – Construction (2011), we are of the view that the bulk fill materials that were placed on this Lot by Winslow Constructors Pty Ltd can be considered as being placed in a controlled manner to a minimum density ratio of 95% (standard compactive effort).

### LIMITATIONS

The use of this Certificate is only appropriate for the field conditions present up to June 2016.

A handwritten signature in black ink, appearing to read 'Griffin Brown', is written over a light blue horizontal line.

Griffin Brown



---

## FILL CERTIFICATE

PROJECT: Lot No 228 (as per Drawing No 12369-202-C02)  
Haven Estate (Stage 2), Tarneit

CLIENT: Peets Funds Management Pty Ltd  
Level 3, 492 St Kilda Road  
MELBOURNE VIC 3004

REPORT NO: 16286\_228

DATE: 14/06/16

---

### SUMMARY

Civil Geotechnical Services were engaged by Winslow Constructors Pty Ltd to provide inspection and testing services on the earthworks associated with Lot 228 of Haven Estate (Stage 2), Tarneit, in a manner which would satisfy the criteria for Level 1 Supervision as specified in Section 8.2 of AS 3798 - Guidelines on Earthworks for Commercial and Residential Developments - 2007. The project was classified as Type 1/2 requiring a minimum density ratio of 95.0% (standard compactive effort) within the area of fill placement.

A site inspection was conducted prior to any fill being placed on the Lot. On the completion of earthworks and after examining the test results and the materials used, we are of the opinion that the filling procedure conducted by Winslow Constructors Pty Ltd satisfied the requirements of AS 3798 in regard to the placement of fill on a Type 1/2 Project under Level 1 Supervision.

Accordingly, when classifying the site in accordance with the procedures presented in Section 2 of AS 2870 – Residential Slabs and Footings – Construction (2011), we are of the view that the bulk fill materials that were placed on this Lot by Winslow Constructors Pty Ltd can be considered as being placed in a controlled manner to a minimum density ratio of 95% (standard compactive effort).

### LIMITATIONS

The use of this Certificate is only appropriate for the field conditions present up to June 2016.

A handwritten signature in black ink, appearing to read 'Griffin Brown', is written over a light blue horizontal line.

Griffin Brown



---

## FILL CERTIFICATE

PROJECT: Lot No 229 (as per Drawing No 12369-202-C02)  
Haven Estate (Stage 2), Tarneit

CLIENT: Peets Funds Management Pty Ltd  
Level 3, 492 St Kilda Road  
MELBOURNE VIC 3004

REPORT NO: 16286\_229

DATE: 14/06/16

---

### SUMMARY

Civil Geotechnical Services were engaged by Winslow Constructors Pty Ltd to provide inspection and testing services on the earthworks associated with Lot 229 of Haven Estate (Stage 2), Tarneit, in a manner which would satisfy the criteria for Level 1 Supervision as specified in Section 8.2 of AS 3798 - Guidelines on Earthworks for Commercial and Residential Developments - 2007. The project was classified as Type 1/2 requiring a minimum density ratio of 95.0% (standard compactive effort) within the area of fill placement.

A site inspection was conducted prior to any fill being placed on the Lot. On the completion of earthworks and after examining the test results and the materials used, we are of the opinion that the filling procedure conducted by Winslow Constructors Pty Ltd satisfied the requirements of AS 3798 in regard to the placement of fill on a Type 1/2 Project under Level 1 Supervision.

Accordingly, when classifying the site in accordance with the procedures presented in Section 2 of AS 2870 – Residential Slabs and Footings – Construction (2011), we are of the view that the bulk fill materials that were placed on this Lot by Winslow Constructors Pty Ltd can be considered as being placed in a controlled manner to a minimum density ratio of 95% (standard compactive effort).

### LIMITATIONS

The use of this Certificate is only appropriate for the field conditions present up to June 2016.

A handwritten signature in black ink, appearing to read 'Griffin Brown', is written over a light blue horizontal line.

Griffin Brown



---

## FILL CERTIFICATE

PROJECT: Lot No 230 (as per Drawing No 12369-202-C02)  
Haven Estate (Stage 2), Tarneit

CLIENT: Peets Funds Management Pty Ltd  
Level 3, 492 St Kilda Road  
MELBOURNE VIC 3004

REPORT NO: 16286\_230

DATE: 14/06/16

---

### SUMMARY

Civil Geotechnical Services were engaged by Winslow Constructors Pty Ltd to provide inspection and testing services on the earthworks associated with Lot 230 of Haven Estate (Stage 2), Tarneit, in a manner which would satisfy the criteria for Level 1 Supervision as specified in Section 8.2 of AS 3798 - Guidelines on Earthworks for Commercial and Residential Developments - 2007. The project was classified as Type 1/2 requiring a minimum density ratio of 95.0% (standard compactive effort) within the area of fill placement.

A site inspection was conducted prior to any fill being placed on the Lot. On the completion of earthworks and after examining the test results and the materials used, we are of the opinion that the filling procedure conducted by Winslow Constructors Pty Ltd satisfied the requirements of AS 3798 in regard to the placement of fill on a Type 1/2 Project under Level 1 Supervision.

Accordingly, when classifying the site in accordance with the procedures presented in Section 2 of AS 2870 – Residential Slabs and Footings – Construction (2011), we are of the view that the bulk fill materials that were placed on this Lot by Winslow Constructors Pty Ltd can be considered as being placed in a controlled manner to a minimum density ratio of 95% (standard compactive effort).

### LIMITATIONS

The use of this Certificate is only appropriate for the field conditions present up to June 2016.

A handwritten signature in black ink, appearing to read 'Griffin Brown', is written over a light blue horizontal line.

Griffin Brown



---

## FILL CERTIFICATE

PROJECT: Lot No 231 (as per Drawing No 12369-202-C02)  
Haven Estate (Stage 2), Tarneit

CLIENT: Peets Funds Management Pty Ltd  
Level 3, 492 St Kilda Road  
MELBOURNE VIC 3004

REPORT NO: 16286\_231

DATE: 14/06/16

---

### SUMMARY

Civil Geotechnical Services were engaged by Winslow Constructors Pty Ltd to provide inspection and testing services on the earthworks associated with Lot 231 of Haven Estate (Stage 2), Tarneit, in a manner which would satisfy the criteria for Level 1 Supervision as specified in Section 8.2 of AS 3798 - Guidelines on Earthworks for Commercial and Residential Developments - 2007. The project was classified as Type 1/2 requiring a minimum density ratio of 95.0% (standard compactive effort) within the area of fill placement.

A site inspection was conducted prior to any fill being placed on the Lot. On the completion of earthworks and after examining the test results and the materials used, we are of the opinion that the filling procedure conducted by Winslow Constructors Pty Ltd satisfied the requirements of AS 3798 in regard to the placement of fill on a Type 1/2 Project under Level 1 Supervision.

Accordingly, when classifying the site in accordance with the procedures presented in Section 2 of AS 2870 – Residential Slabs and Footings – Construction (2011), we are of the view that the bulk fill materials that were placed on this Lot by Winslow Constructors Pty Ltd can be considered as being placed in a controlled manner to a minimum density ratio of 95% (standard compactive effort).

### LIMITATIONS

The use of this Certificate is only appropriate for the field conditions present up to June 2016.

A handwritten signature in black ink, appearing to read 'Griffin Brown', is written over a light blue horizontal line.

Griffin Brown



---

## FILL CERTIFICATE

PROJECT: Lot No 232 (as per Drawing No 12369-202-C02)  
Haven Estate (Stage 2), Tarneit

CLIENT: Peets Funds Management Pty Ltd  
Level 3, 492 St Kilda Road  
MELBOURNE VIC 3004

REPORT NO: 16286\_232

DATE: 14/06/16

---

### SUMMARY

Civil Geotechnical Services were engaged by Winslow Constructors Pty Ltd to provide inspection and testing services on the earthworks associated with Lot 232 of Haven Estate (Stage 2), Tarneit, in a manner which would satisfy the criteria for Level 1 Supervision as specified in Section 8.2 of AS 3798 - Guidelines on Earthworks for Commercial and Residential Developments - 2007. The project was classified as Type 1/2 requiring a minimum density ratio of 95.0% (standard compactive effort) within the area of fill placement.

A site inspection was conducted prior to any fill being placed on the Lot. On the completion of earthworks and after examining the test results and the materials used, we are of the opinion that the filling procedure conducted by Winslow Constructors Pty Ltd satisfied the requirements of AS 3798 in regard to the placement of fill on a Type 1/2 Project under Level 1 Supervision.

Accordingly, when classifying the site in accordance with the procedures presented in Section 2 of AS 2870 – Residential Slabs and Footings – Construction (2011), we are of the view that the bulk fill materials that were placed on this Lot by Winslow Constructors Pty Ltd can be considered as being placed in a controlled manner to a minimum density ratio of 95% (standard compactive effort).

### LIMITATIONS

The use of this Certificate is only appropriate for the field conditions present up to June 2016.

A handwritten signature in black ink, appearing to read 'Griffin Brown', is written over a light blue horizontal line.

Griffin Brown



---

## FILL CERTIFICATE

PROJECT: Lot No 233 (as per Drawing No 12369-202-C02)  
Haven Estate (Stage 2), Tarneit

CLIENT: Peets Funds Management Pty Ltd  
Level 3, 492 St Kilda Road  
MELBOURNE VIC 3004

REPORT NO: 16286\_233

DATE: 14/06/16

---

### SUMMARY

Civil Geotechnical Services were engaged by Winslow Constructors Pty Ltd to provide inspection and testing services on the earthworks associated with Lot 233 of Haven Estate (Stage 2), Tarneit, in a manner which would satisfy the criteria for Level 1 Supervision as specified in Section 8.2 of AS 3798 - Guidelines on Earthworks for Commercial and Residential Developments - 2007. The project was classified as Type 1/2 requiring a minimum density ratio of 95.0% (standard compactive effort) within the area of fill placement.

A site inspection was conducted prior to any fill being placed on the Lot. On the completion of earthworks and after examining the test results and the materials used, we are of the opinion that the filling procedure conducted by Winslow Constructors Pty Ltd satisfied the requirements of AS 3798 in regard to the placement of fill on a Type 1/2 Project under Level 1 Supervision.

Accordingly, when classifying the site in accordance with the procedures presented in Section 2 of AS 2870 – Residential Slabs and Footings – Construction (2011), we are of the view that the bulk fill materials that were placed on this Lot by Winslow Constructors Pty Ltd can be considered as being placed in a controlled manner to a minimum density ratio of 95% (standard compactive effort).

### LIMITATIONS

The use of this Certificate is only appropriate for the field conditions present up to June 2016.

A handwritten signature in black ink, appearing to read 'Griffin Brown', is written over a light blue horizontal line.

Griffin Brown



---

## FILL CERTIFICATE

PROJECT: Lot No 234 (as per Drawing No 12369-202-C02)  
Haven Estate (Stage 2), Tarneit

CLIENT: Peets Funds Management Pty Ltd  
Level 3, 492 St Kilda Road  
MELBOURNE VIC 3004

REPORT NO: 16286\_234

DATE: 14/06/16

---

### SUMMARY

Civil Geotechnical Services were engaged by Winslow Constructors Pty Ltd to provide inspection and testing services on the earthworks associated with Lot 234 of Haven Estate (Stage 2), Tarneit, in a manner which would satisfy the criteria for Level 1 Supervision as specified in Section 8.2 of AS 3798 - Guidelines on Earthworks for Commercial and Residential Developments - 2007. The project was classified as Type 1/2 requiring a minimum density ratio of 95.0% (standard compactive effort) within the area of fill placement.

A site inspection was conducted prior to any fill being placed on the Lot. On the completion of earthworks and after examining the test results and the materials used, we are of the opinion that the filling procedure conducted by Winslow Constructors Pty Ltd satisfied the requirements of AS 3798 in regard to the placement of fill on a Type 1/2 Project under Level 1 Supervision.

Accordingly, when classifying the site in accordance with the procedures presented in Section 2 of AS 2870 – Residential Slabs and Footings – Construction (2011), we are of the view that the bulk fill materials that were placed on this Lot by Winslow Constructors Pty Ltd can be considered as being placed in a controlled manner to a minimum density ratio of 95% (standard compactive effort).

### LIMITATIONS

The use of this Certificate is only appropriate for the field conditions present up to June 2016.

A handwritten signature in black ink, appearing to read 'Griffin Brown', is written over a light blue horizontal line.

Griffin Brown



---

## FILL CERTIFICATE

PROJECT: Lot No 235 (as per Drawing No 12369-202-C02)  
Haven Estate (Stage 2), Tarneit

CLIENT: Peets Funds Management Pty Ltd  
Level 3, 492 St Kilda Road  
MELBOURNE VIC 3004

REPORT NO: 16286\_235

DATE: 14/06/16

---

### SUMMARY

Civil Geotechnical Services were engaged by Winslow Constructors Pty Ltd to provide inspection and testing services on the earthworks associated with Lot 235 of Haven Estate (Stage 2), Tarneit, in a manner which would satisfy the criteria for Level 1 Supervision as specified in Section 8.2 of AS 3798 - Guidelines on Earthworks for Commercial and Residential Developments - 2007. The project was classified as Type 1/2 requiring a minimum density ratio of 95.0% (standard compactive effort) within the area of fill placement.

A site inspection was conducted prior to any fill being placed on the Lot. On the completion of earthworks and after examining the test results and the materials used, we are of the opinion that the filling procedure conducted by Winslow Constructors Pty Ltd satisfied the requirements of AS 3798 in regard to the placement of fill on a Type 1/2 Project under Level 1 Supervision.

Accordingly, when classifying the site in accordance with the procedures presented in Section 2 of AS 2870 – Residential Slabs and Footings – Construction (2011), we are of the view that the bulk fill materials that were placed on this Lot by Winslow Constructors Pty Ltd can be considered as being placed in a controlled manner to a minimum density ratio of 95% (standard compactive effort).

### LIMITATIONS

The use of this Certificate is only appropriate for the field conditions present up to June 2016.

A handwritten signature in black ink, appearing to read 'Griffin Brown', is written over a light blue horizontal line.

Griffin Brown



---

## FILL CERTIFICATE

PROJECT: Lot No 236 (as per Drawing No 12369-202-C02)  
Haven Estate (Stage 2), Tarneit

CLIENT: Peets Funds Management Pty Ltd  
Level 3, 492 St Kilda Road  
MELBOURNE VIC 3004

REPORT NO: 16286\_236

DATE: 14/06/16

---

### SUMMARY

Civil Geotechnical Services were engaged by Winslow Constructors Pty Ltd to provide inspection and testing services on the earthworks associated with Lot 236 of Haven Estate (Stage 2), Tarneit, in a manner which would satisfy the criteria for Level 1 Supervision as specified in Section 8.2 of AS 3798 - Guidelines on Earthworks for Commercial and Residential Developments - 2007. The project was classified as Type 1/2 requiring a minimum density ratio of 95.0% (standard compactive effort) within the area of fill placement.

A site inspection was conducted prior to any fill being placed on the Lot. On the completion of earthworks and after examining the test results and the materials used, we are of the opinion that the filling procedure conducted by Winslow Constructors Pty Ltd satisfied the requirements of AS 3798 in regard to the placement of fill on a Type 1/2 Project under Level 1 Supervision.

Accordingly, when classifying the site in accordance with the procedures presented in Section 2 of AS 2870 – Residential Slabs and Footings – Construction (2011), we are of the view that the bulk fill materials that were placed on this Lot by Winslow Constructors Pty Ltd can be considered as being placed in a controlled manner to a minimum density ratio of 95% (standard compactive effort).

### LIMITATIONS

The use of this Certificate is only appropriate for the field conditions present up to June 2016.

A handwritten signature in black ink, appearing to read 'Griffin Brown', written in a cursive style.

Griffin Brown



---

## FILL CERTIFICATE

PROJECT: Lot No 237 (as per Drawing No 12369-202-C02)  
Haven Estate (Stage 2), Tarneit

CLIENT: Peets Funds Management Pty Ltd  
Level 3, 492 St Kilda Road  
MELBOURNE VIC 3004

REPORT NO: 16286\_237

DATE: 14/06/16

---

### SUMMARY

Civil Geotechnical Services were engaged by Winslow Constructors Pty Ltd to provide inspection and testing services on the earthworks associated with Lot 237 of Haven Estate (Stage 2), Tarneit, in a manner which would satisfy the criteria for Level 1 Supervision as specified in Section 8.2 of AS 3798 - Guidelines on Earthworks for Commercial and Residential Developments - 2007. The project was classified as Type 1/2 requiring a minimum density ratio of 95.0% (standard compactive effort) within the area of fill placement.

A site inspection was conducted prior to any fill being placed on the Lot. On the completion of earthworks and after examining the test results and the materials used, we are of the opinion that the filling procedure conducted by Winslow Constructors Pty Ltd satisfied the requirements of AS 3798 in regard to the placement of fill on a Type 1/2 Project under Level 1 Supervision.

Accordingly, when classifying the site in accordance with the procedures presented in Section 2 of AS 2870 – Residential Slabs and Footings – Construction (2011), we are of the view that the bulk fill materials that were placed on this Lot by Winslow Constructors Pty Ltd can be considered as being placed in a controlled manner to a minimum density ratio of 95% (standard compactive effort).

### LIMITATIONS

The use of this Certificate is only appropriate for the field conditions present up to June 2016.

A handwritten signature in black ink, appearing to read 'Griffin Brown', is written over a horizontal line.

Griffin Brown



## FILL CERTIFICATE

PROJECT: Lot No 243 (as per Drawing No 12369-202-C02)  
Haven Estate (Stage 2), Tarneit

CLIENT: Peets Funds Management Pty Ltd  
Level 3, 492 St Kilda Road  
MELBOURNE VIC 3004

REPORT NO: 16286\_243

DATE: 14/06/16

---

### SUMMARY

Civil Geotechnical Services were engaged by Winslow Constructors Pty Ltd to provide inspection and testing services on the earthworks associated with Lot 243 of Haven Estate (Stage 2), Tarneit, in a manner which would satisfy the criteria for Level 1 Supervision as specified in Section 8.2 of AS 3798 - Guidelines on Earthworks for Commercial and Residential Developments - 2007. The project was classified as Type 1/2 requiring a minimum density ratio of 95.0% (standard compactive effort) within the area of fill placement.

A site inspection was conducted prior to any fill being placed on the Lot. On the completion of earthworks and after examining the test results and the materials used, we are of the opinion that the filling procedure conducted by Winslow Constructors Pty Ltd satisfied the requirements of AS 3798 in regard to the placement of fill on a Type 1/2 Project under Level 1 Supervision.

Accordingly, when classifying the site in accordance with the procedures presented in Section 2 of AS 2870 – Residential Slabs and Footings – Construction (2011), we are of the view that the bulk fill materials that were placed on this Lot by Winslow Constructors Pty Ltd can be considered as being placed in a controlled manner to a minimum density ratio of 95% (standard compactive effort).

### LIMITATIONS

The use of this Certificate is only appropriate for the field conditions present up to June 2016.

A handwritten signature in black ink, appearing to read 'Griffin Brown', is written over a horizontal line.

Griffin Brown



---

## FILL CERTIFICATE

PROJECT: Lot No 244 (as per Drawing No 12369-202-C02)  
Haven Estate (Stage 2), Tarneit

CLIENT: Peets Funds Management Pty Ltd  
Level 3, 492 St Kilda Road  
MELBOURNE VIC 3004

REPORT NO: 16286\_244

DATE: 14/06/16

---

### SUMMARY

Civil Geotechnical Services were engaged by Winslow Constructors Pty Ltd to provide inspection and testing services on the earthworks associated with Lot 244 of Haven Estate (Stage 2), Tarneit, in a manner which would satisfy the criteria for Level 1 Supervision as specified in Section 8.2 of AS 3798 - Guidelines on Earthworks for Commercial and Residential Developments - 2007. The project was classified as Type 1/2 requiring a minimum density ratio of 95.0% (standard compactive effort) within the area of fill placement.

A site inspection was conducted prior to any fill being placed on the Lot. On the completion of earthworks and after examining the test results and the materials used, we are of the opinion that the filling procedure conducted by Winslow Constructors Pty Ltd satisfied the requirements of AS 3798 in regard to the placement of fill on a Type 1/2 Project under Level 1 Supervision.

Accordingly, when classifying the site in accordance with the procedures presented in Section 2 of AS 2870 – Residential Slabs and Footings – Construction (2011), we are of the view that the bulk fill materials that were placed on this Lot by Winslow Constructors Pty Ltd can be considered as being placed in a controlled manner to a minimum density ratio of 95% (standard compactive effort).

### LIMITATIONS

The use of this Certificate is only appropriate for the field conditions present up to June 2016.

A handwritten signature in black ink, appearing to read 'Griffin Brown', is written over a horizontal line.

Griffin Brown



---

## FILL CERTIFICATE

PROJECT: Lot No 245 (as per Drawing No 12369-202-C02)  
Haven Estate (Stage 2), Tarneit

CLIENT: Peets Funds Management Pty Ltd  
Level 3, 492 St Kilda Road  
MELBOURNE VIC 3004

REPORT NO: 16286\_245

DATE: 14/06/16

---

### SUMMARY

Civil Geotechnical Services were engaged by Winslow Constructors Pty Ltd to provide inspection and testing services on the earthworks associated with Lot 245 of Haven Estate (Stage 2), Tarneit, in a manner which would satisfy the criteria for Level 1 Supervision as specified in Section 8.2 of AS 3798 - Guidelines on Earthworks for Commercial and Residential Developments - 2007. The project was classified as Type 1/2 requiring a minimum density ratio of 95.0% (standard compactive effort) within the area of fill placement.

A site inspection was conducted prior to any fill being placed on the Lot. On the completion of earthworks and after examining the test results and the materials used, we are of the opinion that the filling procedure conducted by Winslow Constructors Pty Ltd satisfied the requirements of AS 3798 in regard to the placement of fill on a Type 1/2 Project under Level 1 Supervision.

Accordingly, when classifying the site in accordance with the procedures presented in Section 2 of AS 2870 – Residential Slabs and Footings – Construction (2011), we are of the view that the bulk fill materials that were placed on this Lot by Winslow Constructors Pty Ltd can be considered as being placed in a controlled manner to a minimum density ratio of 95% (standard compactive effort).

### LIMITATIONS

The use of this Certificate is only appropriate for the field conditions present up to June 2016.

A handwritten signature in black ink, appearing to read 'Griffin Brown', is written over a light blue horizontal line.

Griffin Brown



---

## FILL CERTIFICATE

PROJECT: Lot No 246 (as per Drawing No 12369-202-C02)  
Haven Estate (Stage 2), Tarneit

CLIENT: Peets Funds Management Pty Ltd  
Level 3, 492 St Kilda Road  
MELBOURNE VIC 3004

REPORT NO: 16286\_246

DATE: 14/06/16

---

### SUMMARY

Civil Geotechnical Services were engaged by Winslow Constructors Pty Ltd to provide inspection and testing services on the earthworks associated with Lot 246 of Haven Estate (Stage 2), Tarneit, in a manner which would satisfy the criteria for Level 1 Supervision as specified in Section 8.2 of AS 3798 - Guidelines on Earthworks for Commercial and Residential Developments - 2007. The project was classified as Type 1/2 requiring a minimum density ratio of 95.0% (standard compactive effort) within the area of fill placement.

A site inspection was conducted prior to any fill being placed on the Lot. On the completion of earthworks and after examining the test results and the materials used, we are of the opinion that the filling procedure conducted by Winslow Constructors Pty Ltd satisfied the requirements of AS 3798 in regard to the placement of fill on a Type 1/2 Project under Level 1 Supervision.

Accordingly, when classifying the site in accordance with the procedures presented in Section 2 of AS 2870 – Residential Slabs and Footings – Construction (2011), we are of the view that the bulk fill materials that were placed on this Lot by Winslow Constructors Pty Ltd can be considered as being placed in a controlled manner to a minimum density ratio of 95% (standard compactive effort).

### LIMITATIONS

The use of this Certificate is only appropriate for the field conditions present up to June 2016.

A handwritten signature in black ink, appearing to read 'Griffin Brown', is written over a light blue horizontal line.

Griffin Brown



## FILL CERTIFICATE

PROJECT: Lot No 247 (as per Drawing No 12369-202-C02)  
Haven Estate (Stage 2), Tarneit

CLIENT: Peets Funds Management Pty Ltd  
Level 3, 492 St Kilda Road  
MELBOURNE VIC 3004

REPORT NO: 16286\_247

DATE: 14/06/16

---

### SUMMARY

Civil Geotechnical Services were engaged by Winslow Constructors Pty Ltd to provide inspection and testing services on the earthworks associated with Lot 247 of Haven Estate (Stage 2), Tarneit, in a manner which would satisfy the criteria for Level 1 Supervision as specified in Section 8.2 of AS 3798 - Guidelines on Earthworks for Commercial and Residential Developments - 2007. The project was classified as Type 1/2 requiring a minimum density ratio of 95.0% (standard compactive effort) within the area of fill placement.

A site inspection was conducted prior to any fill being placed on the Lot. On the completion of earthworks and after examining the test results and the materials used, we are of the opinion that the filling procedure conducted by Winslow Constructors Pty Ltd satisfied the requirements of AS 3798 in regard to the placement of fill on a Type 1/2 Project under Level 1 Supervision.

Accordingly, when classifying the site in accordance with the procedures presented in Section 2 of AS 2870 – Residential Slabs and Footings – Construction (2011), we are of the view that the bulk fill materials that were placed on this Lot by Winslow Constructors Pty Ltd can be considered as being placed in a controlled manner to a minimum density ratio of 95% (standard compactive effort).

### LIMITATIONS

The use of this Certificate is only appropriate for the field conditions present up to June 2016.

A handwritten signature in black ink, appearing to read 'Griffin Brown'.

Griffin Brown