



FILL CERTIFICATE

PROJECT: Lot No 201 (as per Drawing No 8890 E02)
Cornerstone Estate – Stage 2

CLIENT: Winslow Constructors Pty Ltd
50 Barry Road
CAMPBELLFIELD VIC 3061

REPORT NO: 17321_201

DATE: 13/06/17

SUMMARY

Civil Geotechnical Services were engaged by Winslow Constructors Pty Ltd to provide inspection and testing services on the earthworks associated with Lot 201 of Cornerstone Estate (Stage 2), Wyndham Vale in a manner which would satisfy the criteria for Level 1 Supervision as specified in Section 8.2 of AS 3798 - Guidelines on Earthworks for Commercial and Residential Developments - 2007. The project was classified as Type 1/2 requiring a minimum density ratio of 95.0% (standard compactive effort) within the area of fill placement.

A site inspection was conducted prior to any fill being placed on the Lot. On the completion of earthworks and after examining the test results and the materials used, we are of the opinion that the filling procedure conducted by Winslow Constructors Pty Ltd satisfied the requirements of AS 3798 in regard to the placement of fill on a Type 1/2 Project under Level 1 Supervision.

Accordingly, when classifying the site in accordance with the procedures presented in Section 2 of AS 2870 – Residential Slabs and Footings – Construction (2011), we are of the view that the bulk fill materials that were placed on this Lot by Winslow Constructors Pty Ltd can be considered as being placed in a controlled manner to a minimum density ratio of 95% (standard compactive effort).

LIMITATIONS

The use of this Certificate is only appropriate for the field conditions present up to 8th June 2017.

A handwritten signature in black ink, appearing to read 'Griffin Brown', is written over a light blue horizontal line.

Griffin Brown



FILL CERTIFICATE

PROJECT: Lot No 202 (as per Drawing No 8890 E02)
Cornerstone Estate – Stage 2

CLIENT: Winslow Constructors Pty Ltd
50 Barry Road
CAMPBELLFIELD VIC 3061

REPORT NO: 17321_202

DATE: 13/06/17

SUMMARY

Civil Geotechnical Services were engaged by Winslow Constructors Pty Ltd to provide inspection and testing services on the earthworks associated with Lot 202 of Cornerstone Estate (Stage 2), Wyndham Vale in a manner which would satisfy the criteria for Level 1 Supervision as specified in Section 8.2 of AS 3798 - Guidelines on Earthworks for Commercial and Residential Developments - 2007. The project was classified as Type 1/2 requiring a minimum density ratio of 95.0% (standard compactive effort) within the area of fill placement.

A site inspection was conducted prior to any fill being placed on the Lot. On the completion of earthworks and after examining the test results and the materials used, we are of the opinion that the filling procedure conducted by Winslow Constructors Pty Ltd satisfied the requirements of AS 3798 in regard to the placement of fill on a Type 1/2 Project under Level 1 Supervision.

Accordingly, when classifying the site in accordance with the procedures presented in Section 2 of AS 2870 – Residential Slabs and Footings – Construction (2011), we are of the view that the bulk fill materials that were placed on this Lot by Winslow Constructors Pty Ltd can be considered as being placed in a controlled manner to a minimum density ratio of 95% (standard compactive effort).

LIMITATIONS

The use of this Certificate is only appropriate for the field conditions present up to 8th June 2017.

A handwritten signature in black ink, appearing to read 'Griffin Brown', is written over a light blue horizontal line.

Griffin Brown



FILL CERTIFICATE

PROJECT: Lot No 203 (as per Drawing No 8890 E02)
Cornerstone Estate – Stage 2

CLIENT: Winslow Constructors Pty Ltd
50 Barry Road
CAMPBELLFIELD VIC 3061

REPORT NO: 17321_203

DATE: 13/06/17

SUMMARY

Civil Geotechnical Services were engaged by Winslow Constructors Pty Ltd to provide inspection and testing services on the earthworks associated with the construction of the Cornerstone Estate (Stage 2), Wyndham Vale in a manner which would satisfy the criteria for Level 1 Supervision as specified in Section 8.2 of AS 3798 - Guidelines on Earthworks for Commercial and Residential Developments - 2007. The project was classified as Type 1/2 requiring a minimum density ratio of 95.0% (standard compactive effort) within the area of fill placement.

A site inspection was conducted prior to any fill being placed on the allotments. On the completion of the earthworks and after examining the materials used, we are of the opinion that the filling procedure conducted by Winslow Constructors Pty Ltd during the construction of the estate satisfied the requirements of AS 3798 in regard to the placement of fill on a Type 1/2 Project under Level 1 Supervision.

With respect to Lot 201, the depth of fill materials that were placed during the current construction phase (excluding top soiling activities) was less than 0.3 metres. As a consequence of the limited depth of fill materials, field density testing was not considered warranted. However, when classifying the site in accordance with the procedures presented in Section 2 of AS 2870 – Residential Slabs and Footings – Construction (2011), we are of the view that the bulk fill materials that were placed on this Lot by Winslow Constructors Pty Ltd can be considered as being placed in a controlled manner to a minimum density ratio of 95% (standard compactive effort).

LIMITATIONS

The use of this Certificate is only appropriate for the field conditions present up to 8th June 2017.

A handwritten signature in black ink, appearing to read 'Griffin Brown'.

Griffin Brown



FILL CERTIFICATE

PROJECT: Lot No 216 (as per Drawing No 8890 E02)
Cornerstone Estate – Stage 2

CLIENT: Winslow Constructors Pty Ltd
50 Barry Road
CAMPBELLFIELD VIC 3061

REPORT NO: 17321_216

DATE: 13/06/17

SUMMARY

Civil Geotechnical Services were engaged by Winslow Constructors Pty Ltd to provide inspection and testing services on the earthworks associated with Lot 216 of Cornerstone Estate (Stage 2), Wyndham Vale in a manner which would satisfy the criteria for Level 1 Supervision as specified in Section 8.2 of AS 3798 - Guidelines on Earthworks for Commercial and Residential Developments - 2007. The project was classified as Type 1/2 requiring a minimum density ratio of 95.0% (standard compactive effort) within the area of fill placement.

A site inspection was conducted prior to any fill being placed on the Lot. On the completion of earthworks and after examining the test results and the materials used, we are of the opinion that the filling procedure conducted by Winslow Constructors Pty Ltd satisfied the requirements of AS 3798 in regard to the placement of fill on a Type 1/2 Project under Level 1 Supervision.

Accordingly, when classifying the site in accordance with the procedures presented in Section 2 of AS 2870 – Residential Slabs and Footings – Construction (2011), we are of the view that the bulk fill materials that were placed on this Lot by Winslow Constructors Pty Ltd can be considered as being placed in a controlled manner to a minimum density ratio of 95% (standard compactive effort).

LIMITATIONS

The use of this Certificate is only appropriate for the field conditions present up to 8th June 2017.

A handwritten signature in black ink, appearing to read 'Griffin Brown', is written over a light blue horizontal line.

Griffin Brown



FILL CERTIFICATE

PROJECT: Lot No 217 (as per Drawing No 8890 E02)
Cornerstone Estate – Stage 2

CLIENT: Winslow Constructors Pty Ltd
50 Barry Road
CAMPBELLFIELD VIC 3061

REPORT NO: 17321_217

DATE: 13/06/17

SUMMARY

Civil Geotechnical Services were engaged by Winslow Constructors Pty Ltd to provide inspection and testing services on the earthworks associated with Lot 217 of Cornerstone Estate (Stage 2), Wyndham Vale in a manner which would satisfy the criteria for Level 1 Supervision as specified in Section 8.2 of AS 3798 - Guidelines on Earthworks for Commercial and Residential Developments - 2007. The project was classified as Type 1/2 requiring a minimum density ratio of 95.0% (standard compactive effort) within the area of fill placement.

A site inspection was conducted prior to any fill being placed on the Lot. On the completion of earthworks and after examining the test results and the materials used, we are of the opinion that the filling procedure conducted by Winslow Constructors Pty Ltd satisfied the requirements of AS 3798 in regard to the placement of fill on a Type 1/2 Project under Level 1 Supervision.

Accordingly, when classifying the site in accordance with the procedures presented in Section 2 of AS 2870 – Residential Slabs and Footings – Construction (2011), we are of the view that the bulk fill materials that were placed on this Lot by Winslow Constructors Pty Ltd can be considered as being placed in a controlled manner to a minimum density ratio of 95% (standard compactive effort).

LIMITATIONS

The use of this Certificate is only appropriate for the field conditions present up to 8th June 2017.

A handwritten signature in black ink, appearing to read 'Griffin Brown', is written over a light blue horizontal line.

Griffin Brown



FILL CERTIFICATE

PROJECT: Lot No 218 (as per Drawing No 8890 E02)
Cornerstone Estate – Stage 2

CLIENT: Winslow Constructors Pty Ltd
50 Barry Road
CAMPBELLFIELD VIC 3061

REPORT NO: 17321_218

DATE: 13/06/17

SUMMARY

Civil Geotechnical Services were engaged by Winslow Constructors Pty Ltd to provide inspection and testing services on the earthworks associated with Lot 218 of Cornerstone Estate (Stage 2), Wyndham Vale in a manner which would satisfy the criteria for Level 1 Supervision as specified in Section 8.2 of AS 3798 - Guidelines on Earthworks for Commercial and Residential Developments - 2007. The project was classified as Type 1/2 requiring a minimum density ratio of 95.0% (standard compactive effort) within the area of fill placement.

A site inspection was conducted prior to any fill being placed on the Lot. On the completion of earthworks and after examining the test results and the materials used, we are of the opinion that the filling procedure conducted by Winslow Constructors Pty Ltd satisfied the requirements of AS 3798 in regard to the placement of fill on a Type 1/2 Project under Level 1 Supervision.

Accordingly, when classifying the site in accordance with the procedures presented in Section 2 of AS 2870 – Residential Slabs and Footings – Construction (2011), we are of the view that the bulk fill materials that were placed on this Lot by Winslow Constructors Pty Ltd can be considered as being placed in a controlled manner to a minimum density ratio of 95% (standard compactive effort).

LIMITATIONS

The use of this Certificate is only appropriate for the field conditions present up to 8th June 2017.

A handwritten signature in black ink, appearing to read 'Griffin Brown', is written over a light blue horizontal line.

Griffin Brown



FILL CERTIFICATE

PROJECT: Lot No 219 (as per Drawing No 8890 E02)
Cornerstone Estate – Stage 2

CLIENT: Winslow Constructors Pty Ltd
50 Barry Road
CAMPBELLFIELD VIC 3061

REPORT NO: 17321_219

DATE: 13/06/17

SUMMARY

Civil Geotechnical Services were engaged by Winslow Constructors Pty Ltd to provide inspection and testing services on the earthworks associated with the construction of the Cornerstone Estate (Stage 2), Wyndham Vale in a manner which would satisfy the criteria for Level 1 Supervision as specified in Section 8.2 of AS 3798 - Guidelines on Earthworks for Commercial and Residential Developments - 2007. The project was classified as Type 1/2 requiring a minimum density ratio of 95.0% (standard compactive effort) within the area of fill placement.

A site inspection was conducted prior to any fill being placed on the allotments. On the completion of the earthworks and after examining the materials used, we are of the opinion that the filling procedure conducted by Winslow Constructors Pty Ltd during the construction of the estate satisfied the requirements of AS 3798 in regard to the placement of fill on a Type 1/2 Project under Level 1 Supervision.

With respect to Lot 219, the depth of fill materials that were placed during the current construction phase (excluding top soiling activities) was less than 0.3 metres. As a consequence of the limited depth of fill materials, field density testing was not considered warranted. However, when classifying the site in accordance with the procedures presented in Section 2 of AS 2870 – Residential Slabs and Footings – Construction (2011), we are of the view that the bulk fill materials that were placed on this Lot by Winslow Constructors Pty Ltd can be considered as being placed in a controlled manner to a minimum density ratio of 95% (standard compactive effort).

LIMITATIONS

The use of this Certificate is only appropriate for the field conditions present up to 8th June 2017.

A handwritten signature in black ink, appearing to read 'Griffin Brown'.

Griffin Brown



FILL CERTIFICATE

PROJECT: Lot No 220 (as per Drawing No 8890 E02)
Cornerstone Estate – Stage 2

CLIENT: Winslow Constructors Pty Ltd
50 Barry Road
CAMPBELLFIELD VIC 3061

REPORT NO: 17321_220

DATE: 13/06/17

SUMMARY

Civil Geotechnical Services were engaged by Winslow Constructors Pty Ltd to provide inspection and testing services on the earthworks associated with the construction of the Cornerstone Estate (Stage 2), Wyndham Vale in a manner which would satisfy the criteria for Level 1 Supervision as specified in Section 8.2 of AS 3798 - Guidelines on Earthworks for Commercial and Residential Developments - 2007. The project was classified as Type 1/2 requiring a minimum density ratio of 95.0% (standard compactive effort) within the area of fill placement.

A site inspection was conducted prior to any fill being placed on the allotments. On the completion of the earthworks and after examining the materials used, we are of the opinion that the filling procedure conducted by Winslow Constructors Pty Ltd during the construction of the estate satisfied the requirements of AS 3798 in regard to the placement of fill on a Type 1/2 Project under Level 1 Supervision.

With respect to Lot 220, the depth of fill materials that were placed during the current construction phase (excluding top soiling activities) was less than 0.3 metres. As a consequence of the limited depth of fill materials, field density testing was not considered warranted. However, when classifying the site in accordance with the procedures presented in Section 2 of AS 2870 – Residential Slabs and Footings – Construction (2011), we are of the view that the bulk fill materials that were placed on this Lot by Winslow Constructors Pty Ltd can be considered as being placed in a controlled manner to a minimum density ratio of 95% (standard compactive effort).

LIMITATIONS

The use of this Certificate is only appropriate for the field conditions present up to 8th June 2017.

A handwritten signature in black ink, appearing to read 'Griffin Brown'.

Griffin Brown



FILL CERTIFICATE

PROJECT: Lot No 221 (as per Drawing No 8890 E02)
Cornerstone Estate – Stage 2

CLIENT: Winslow Constructors Pty Ltd
50 Barry Road
CAMPBELLFIELD VIC 3061

REPORT NO: 17321_221

DATE: 13/06/17

SUMMARY

Civil Geotechnical Services were engaged by Winslow Constructors Pty Ltd to provide inspection and testing services on the earthworks associated with the construction of the Cornerstone Estate (Stage 2), Wyndham Vale in a manner which would satisfy the criteria for Level 1 Supervision as specified in Section 8.2 of AS 3798 - Guidelines on Earthworks for Commercial and Residential Developments - 2007. The project was classified as Type 1/2 requiring a minimum density ratio of 95.0% (standard compactive effort) within the area of fill placement.

A site inspection was conducted prior to any fill being placed on the allotments. On the completion of the earthworks and after examining the materials used, we are of the opinion that the filling procedure conducted by Winslow Constructors Pty Ltd during the construction of the estate satisfied the requirements of AS 3798 in regard to the placement of fill on a Type 1/2 Project under Level 1 Supervision.

With respect to Lot 221, the depth of fill materials that were placed during the current construction phase (excluding top soiling activities) was less than 0.3 metres. As a consequence of the limited depth of fill materials, field density testing was not considered warranted. However, when classifying the site in accordance with the procedures presented in Section 2 of AS 2870 – Residential Slabs and Footings – Construction (2011), we are of the view that the bulk fill materials that were placed on this Lot by Winslow Constructors Pty Ltd can be considered as being placed in a controlled manner to a minimum density ratio of 95% (standard compactive effort).

LIMITATIONS

The use of this Certificate is only appropriate for the field conditions present up to 8th June 2017.

A handwritten signature in black ink, appearing to read 'Griffin Brown'.

Griffin Brown



FILL CERTIFICATE

PROJECT: Lot No 222 (as per Drawing No 8890 E02)
Cornerstone Estate – Stage 2

CLIENT: Winslow Constructors Pty Ltd
50 Barry Road
CAMPBELLFIELD VIC 3061

REPORT NO: 17321_222

DATE: 13/06/17

SUMMARY

Civil Geotechnical Services were engaged by Winslow Constructors Pty Ltd to provide inspection and testing services on the earthworks associated with the construction of the Cornerstone Estate (Stage 2), Wyndham Vale in a manner which would satisfy the criteria for Level 1 Supervision as specified in Section 8.2 of AS 3798 - Guidelines on Earthworks for Commercial and Residential Developments - 2007. The project was classified as Type 1/2 requiring a minimum density ratio of 95.0% (standard compactive effort) within the area of fill placement.

A site inspection was conducted prior to any fill being placed on the allotments. On the completion of the earthworks and after examining the materials used, we are of the opinion that the filling procedure conducted by Winslow Constructors Pty Ltd during the construction of the estate satisfied the requirements of AS 3798 in regard to the placement of fill on a Type 1/2 Project under Level 1 Supervision.

With respect to Lot 222, the depth of fill materials that were placed during the current construction phase (excluding top soiling activities) was less than 0.3 metres. As a consequence of the limited depth of fill materials, field density testing was not considered warranted. However, when classifying the site in accordance with the procedures presented in Section 2 of AS 2870 – Residential Slabs and Footings – Construction (2011), we are of the view that the bulk fill materials that were placed on this Lot by Winslow Constructors Pty Ltd can be considered as being placed in a controlled manner to a minimum density ratio of 95% (standard compactive effort).

LIMITATIONS

The use of this Certificate is only appropriate for the field conditions present up to 8th June 2017.

A handwritten signature in black ink, appearing to read 'Griffin Brown'.

Griffin Brown